


Net Zero Grid Pathways 1

Major Capex Proposal (Staged) – updated

25 September 2023



Contents


1.0 Executive Summary	4
1.1 Key messages	5
1.2 Context	5
1.3 The project	6
1.4 Net Zero Grid Pathways	7
1.4.1 Staging	8
1.4.2 How we decide to invest	8
1.5 Scenarios	10
1.6 Our proposal – NZGP Phase 1	10
1.6.1 Overview.....	11
1.6.2 Project outcomes.....	14
1.6.3 Timing	16
1.6.4 NZGP1.1 P50 costs and Maximum Capex Allowance	18
1.6.5 Previous consultations	21
1.7 NZGP Phase 2	26
2.0 Need for investment	27
2.1 Existing system	28
2.1.1 Inter- Island High Voltage Direct Current (HVDC) link.....	29
2.1.2 Central North Island (CNI)	31
2.1.3 Wairakei Ring.....	32
2.1.4 Other North Island constraints.....	33
2.2 Overview of the need for investigation and investment	35
2.2.1 HVDC capacity	36
2.2.2 CNI 220 kV	37
2.2.3 HVDC and CNI timing.....	37
2.2.4 Wairakei Ring.....	37
2.2.5 Wairakei timing	38
2.3 Relevant asset condition issues	38
2.3.1 Condition of Pole 2 Equipment and HVDC Cables.....	38
2.3.2 Condition of CNI and Wairakei Ring lines.....	38
2.3.3 Good electricity industry practice	39
2.4 Key factors affecting our application	39
2.4.1 Significant uncertainty.....	39
2.4.2 A least regrets approach	40
2.4.3 Timeliness and preparatory costs	40



2.4.4 Managing our workforce	41
2.4.5 Transmission outages	42
2.4.6 Approval expiry date	42
3.0 Regulatory process for the approval of investments expected to cost more than \$20 million.....	43
3.1 Regulatory process	44
3.2 Transpower process	44
3.3 Treatment of non-transmission solutions	45
4.0 Long and Short-list of options	46
4.1 Options.....	47
4.1.1 Shortlisting criteria	47
4.1.2 Intermediate development plan options	48
4.1.3 Evaluating the intermediate list of HVDC and CNI options	50
4.1.4 Evaluating the intermediate list of Wairakei Ring options.....	50
4.2 Short-listed development plan options	51
4.2.1 Bypassing the existing grid	51
4.2.2 Final short-list of options for Investment Test analysis.....	53
5.0 Options analysis.....	54
5.1 Investment Test approach.....	55
5.1.1 Project costs	55
5.1.2 Expected net electricity market benefit	56
5.1.3 Passing the Investment Test.....	57
5.1.4 Sensitivity analysis.....	57
5.2 Our application of the Investment Test	58
5.2.1 Determining net electricity market benefit.....	59
5.2.2 Investment Test results	60
5.3 Investment Test Sensitivities.....	64
5.4 Preparatory costs.....	67
5.5 MCA calculation.....	68
Appendix A: Expected impact on transmission charges	69
A.1 Relationship of the TPM with the Investment Test	70
Appendix B: List of Figures and Tables	71



1.0 Executive Summary



1.1 Key messages

Figure 1: Key messages

To successfully meet the climate change challenge, Aotearoa New Zealand will need significant investment in electricity transmission infrastructure between now and 2050.

Considerable uncertainties around how demand and supply will ramp-up, make it challenging to plan and develop new infrastructure.

Using a range of future scenarios, our analysis indicates that significant intermittent generation is likely to be built in the upper North Island and firmed by hydro generation in both the North and South islands.

Our proposal increases transfer capacity in the transmission corridor connecting these regions enabling firming of upper North Island intermittent generation. Secondly, our proposal enables more new generation to be connected in the South Island, lower North Island and around the Wairakei Ring. Thirdly, by enabling more transfer over our grid backbone – away from our ageing, constrained 110 kV lines, on to our 220 kV lines, our proposal reduces transmission losses.

Our upgrades extract capacity from the existing grid backbone. These are relatively low-cost grid investments that are low regrets under the future scenarios.

Combined, the benefits of these upgrades provide options and confidence for investors in generation that would not exist if we focused on smaller incremental investments.

Progressing these investments as a package enables forward work planning to ensure timely delivery, and allows Transpower to work on planning, consenting, and developing any larger investments that may be required post 2030.

Our application is for approval to recover the costs of Stage 1 of this proposal only. It is a staged proposal, which provides flexibility to invest in this part of the grid again, but Stage 2 is subject to a new investigation, expected to get underway in 2023.

1.2 Context

Aotearoa New Zealand is on a journey towards a net zero carbon emissions future, working to respond and adapt to climate change. Meeting the country’s 2050 net zero carbon emissions target will require rapid transformation of the energy sector, which will affect almost all aspects of our daily lives. Transpower is committed to playing our part in the transition while continuing to deliver reliable electricity for New Zealanders. We are a critical enabler for other sectors to reach their net zero emissions objectives. We have roles in enabling both electrification demand and the connection of renewable energy.

For Aotearoa New Zealand to shift away from fossil fuel-based energy, consumers and industry need confidence that electricity will be reliable and affordable. Significant (large scale) investment in transmission infrastructure is likely to be necessary to achieve the least cost transition to a net zero emissions economy.

Aotearoa New Zealand's electricity system is market-led rather than centrally planned. For generation to meet future demand at the lowest cost, investors in new generation need us to provide long term transmission grid development plans to support their investment decision making.

The Government has endorsed our role, stating in a letter from the Minister of Energy:

"We continue to expect Transpower to invest ahead of transmission demand in order to ensure that there is capacity for competitive investment by generators in distant load renewables, including intermittent renewables. Transpower's work in this area, and in facilitating the decarbonisation of industrial heat and transport, will help support the Government's targets to achieve 100 per cent renewable electricity by 2030, and reach net zero emissions by 2050."¹

1.3 The project

Net Zero Grid Pathways (NZGP) is our project to develop plans for evolving the transmission grid as New Zealand pursues a goal of achieving net zero carbon emissions by 2050.

Industry forecasts, including our own [Whakamana i Te Mauri Hiko](#) (WiTMH), point toward a 60-80 per cent increase in electricity demand by 2050. This demand will be met by renewable generation. However, the role that various energy sources such as electricity, hydrogen and biomass will play in our future energy mix is not yet clear.

Making a case for, planning, and developing new transmission infrastructure for the expected ramp up of demand and supply from 2025 is an intensive task. The challenge is deepened by key uncertainties. Whether the New Zealand Aluminium Smelter at Tiwai Point closes or not, when and where the next renewable generation projects will be built, decisions around the NZ Battery Project, and whether offshore wind will be developed in New Zealand, will affect what transmission investment is needed. The speed of uptake of electric vehicles, the reduction in fossil fuelled production of process heat, and the evolution of distributed energy resources will also have an impact on transmission investment decisions. Changes to the Resource Management Act and other regulatory amendments also contribute to uncertainty around how we can best ensure a reliable and safe network within a net zero carbon emissions future.

This level of uncertainty is challenging. Whatever future plays out, the overarching demand pathway is clear and Transpower needs to increase the capacity of some parts of the grid backbone in the medium term to ensure capacity is available to deliver the benefits of further investments in low-cost renewable generation.

It is clear that we need to develop the grid flexibly, in a proactive manner. We need to minimise the risk of over-build while ensuring the grid is fit-for-purpose. This will allow Aotearoa New Zealand to handle any of the wide variety of futures we could face.


¹ [Letter of Expectations 2022/23 from the Responsible Minister - Transpower New Zealand Limited](#) (treasury.govt.nz)

As detailed in the recent [The Future is Electric](#) report from Boston Consulting Group:

“This will require unprecedented levels of investment but will lead to flat household electricity bills and declining household energy bills.... Delivering this will require a much smarter, more flexible electricity system that saves \$10 billion in net present value terms by 2050.”

Our NZGP1 proposal is the first Major Capital Proposal (MCP) to be submitted to the Commerce Commission (Commission) for approval under NZGP. It covers the first stage of the first phase of NZGP including improvements to the inter-island capacity of the HVDC, increases in Central North Island 220 kV capacity between Bunnythorpe and Whakamaru, and increases to Wairakei Ring capacity.

Figure 2: Transpower’s enabling role in support of goal to reach net-zero carbon by 2050



1.4 Net Zero Grid Pathways

Electricity flows over the grid backbone are determined by the competitive electricity market rather than local demand peaks and troughs. As a result, the peaks, which drive our investment needs on the backbone grid, are difficult to predict. In the future, when North Island thermal generation is retired, peak usage may become more aligned with the strength of the wind and cloud cover, which is even less predictable.

NZGP aims to ensure the grid backbone has enough capacity to accommodate new renewable generation and maintain a secure and reliable supply of electricity. It has two broad phases:

1. enhance the existing grid backbone over the period to 2035
2. address the likely need for a larger grid backbone with new interconnections beyond 2035 (including regional grid developments).

Our investigations have identified a first stage of least regrets, tactical investments needed for phase one. These are least regrets as they are beneficial under a range of scenarios and mitigate the risk of not having sufficient capacity out to 2035. Importantly, the investments provide generators with confidence to make their own choices about investment. This would not be the case with smaller incremental investments.

Processing these investments as a package enables forward work planning to ensure timely delivery, reduces the churn in sequential approvals, and captures economies of scale.

“Although waiting to invest may appear to be an efficient way to save money, investing in transmission too late stalls the development of low-cost renewable generation, and can therefore increase net prices and emissions.”²

1.4.1 Staging

NZGP has two phases, with two stages within the first phase. Staging ensures we start investing in and expanding the grid, while continuing to refine the scope and costing of projects that will not commence until the late 2020’s. This allows some uncertainty to resolve. We refer to this application as NZGP1.1 as it will be followed by a second stage (NZGP1.2) within the first phase of NZGP. Both NZGP1.1 and NZGP1.2 are aimed at enhancing the grid backbone prior to 2035. We expect to begin our detailed investigations for NZGP1.2 in 2023.

In NZGP Phase 2, we will separately develop and apply for approval of larger future investments that may be required post 2035.

This document is an application to the Commission to recover the costs of investing in the grid to enable the efficient dispatch of new generation and a reliable supply for future demand growth over the interconnected grid. Our application covers only Stage 1 of NZGP1 investments.


We have recognised that our NZGP 1.2 (second stage) investments may occur over a number of years, and it may not be in consumer interests to include them all in a single second stage application. Our NZGP 1.2 application may be split into sub-stages, to ensure timely delivery of some projects.

1.4.2 How we decide to invest

Our NZGP 1 investigations identified several key factors that inform the strategy involved in the choice and timing of investments. These are particularly pertinent when faced with uncertainty, around future electricity demand and supply – as we are now – and are reflected in this MCP. These factors have been used to help determine the short-list of options which are then considered using the Investment Test.

² [The Future is Electric](#) p97

Figure 3: Strategic considerations informing Transpower’s NZGP Stage 1 investment choices



1.5 Scenarios

We based our NZGP scenarios on the Ministry of Business, Innovation and Employment (MBIE) current Electricity Demand and Generation Scenarios (EDGS). However, these were last updated in 2019 and are due for updating in 2023. We understand these updates will be based on a more integrated energy view for achieving net zero carbon emissions by 2050.

With input from the wider industry, we have updated key elements of the 2019 EDGS, including the demand forecasts and information about potential new generation projects.

A summary document describing our variations was published in December 2021.³

1.6 Our proposal – NZGP Phase 1


This MCP is the result of an investigation into:

- Inter-island HVDC capacity
- Central North Island (CNI) 220 kV capacity between Bunnythorpe and Whakamaru
- Wairakei Ring capacity

Based on previous studies and generation connection enquiries, we believe these areas of the grid backbone are the most likely to constrain prior to 2035.

³ [Transpower NZGP Scenarios Update - December 2021](#)

Figure 4: Aotearoa New Zealand transmission grid backbone - the focus of NZGP Phase 1



1.6.1 Overview

The investment need for NZGP1 is defined as:

to enable the efficient dispatch of new generation and a reliable supply for future demand growth over the interconnected grid.

To meet this investment need, this proposal seeks funding approval for

- (1) shorter term initiatives; and
- (2) further investigations into longer-term planning issues and larger investments.

The process is staged. Overall, this is consistent with our least-regrets approach, deferring higher levels of capital investment to allow uncertainties to clarify or play out. This application seeks approval to recover the costs of implementing the first stage (NZGP1.1) only, along with some investigation costs for NZGP 1.2. Approval for the larger and longer-term grid investments (NZGP1.2) will be sought when the need, scope, and cost is more certain.

The total cost of NZGP1.1 is expected to be \$327 million. The major capex allowance we are applying for (including estimates for scope uncertainties, inflation, and interest during construction costs) is

\$393 million. As this transmission enhancement is expected to cost more than \$20 million, Transpower must submit this MCP to the Commission in order to recover the costs through the Transmission Pricing Methodology (TPM).

The grid outputs for NZGP1.1 are as follows:

Table 1: NZGP1.1 at a glance

NZGP1.1 at a glance	
What:	<p>Enable efficient dispatch of new generation and a reliable supply for future demand growth over the interconnected grid through:</p> <p><i>HVDC investment</i></p> <p><i>Outcome: To increase HVDC transfer capacity north from 1070 MW to 1200 MW</i></p> <p><u>Outputs</u></p> <ul style="list-style-type: none"> • Implement new +/-60 MVAR continuous/120 MVAR overload STATCOM, +49MVAR filter bank, bus extension and associated equipment. <p><i>Central North Island (CNI) investments</i></p> <p><i>Outcome: To increase transfer capacity north from Bunnythorpe by between 60% and 90%</i></p> <p><u>Outputs</u></p> <ul style="list-style-type: none"> • Implement Variable Line Rating (VLR) and tactical thermal upgrade (TTU) of both 220 kV circuits on the Tokaanu-Whakamaru A and B lines to 95°C • Duplex the 220 kV Tokaanu-Whakamaru A and B circuits with Goat conductor to operate at a maximum temperature of 120°C • Implement VLR and TTU of the 220 kV Bunnythorpe-Tokaanu A and B circuits to 95°C • Split the 110 kV Bunnythorpe-Ongarue A circuit at Ongarue • Upgrade protection on the 220 kV Huntly-Stratford-1 circuit on the Huntly-Taumaranui A line and Stratford-Taumaranui A line, between Huntly and Stratford • Replace the special protection scheme at Tokaanu <p><i>Outcome: Preparatory work for NZGP1.2 CNI investment:</i></p> <p><u>Outputs</u></p> <ul style="list-style-type: none"> • Investigate options for reconductoring either 220 kV Brunswick-Stratford line • Prepare designs to duplex the 220 kV Bunnythorpe-Tokaanu A and B circuits • Prepare designs to TTU the 220 kV Bunnythorpe-Wairakei A circuits • Investigate options and routes and progress design for a new 220 kV line north of Bunnythorpe • Develop a methodology for quantifying resilience benefits <p><i>HVDC/CNI investments</i></p> <p><i>Outcome: Preparatory work for possible stage 2 CNI investment:</i></p> <p><u>Outputs</u></p> <ul style="list-style-type: none"> • Investigate Lower North Island (LNI) voltage stability • Investigate LNI system stability

	<ul style="list-style-type: none"> Investigate diversifying the Bunnythorpe substation <p>Wairakei investments</p> <p><i>Outcome: To increase Wairakei Ring transmission capacity by 25% (300 MW) under typical operating conditions:</i></p> <p><u>Outputs</u></p> <ul style="list-style-type: none"> TTU the 220 kV Wairakei-Whakamaru C circuits to 100°C TTU of the 220 kV Edgecumbe-Kawerau-3 circuit on the Ohakuri--Edgecumbe A and Kawerau deviation A lines between Edgecumbe and Kawerau to 90°C. <p><i>Outcome: Preparatory work for NZGP1.2 Wairakei Ring investment:</i></p> <p><u>Output</u></p> <ul style="list-style-type: none"> Investigate options and routes and progress designs for a new or enhanced Wairakei-Whakamaru line.
When:	Commence work as soon as funding is approved Commissioning date for last Stage 1 investment: 30 June 2028.
How much:	Major capex allowance: \$393 million
Incentive elements	Major capex incentive rate: 15% Exempt major capex: none
Stage 1 Approval expiry date:	31 December 2035 ⁴

We will seek Commerce Commission approval for staging projects in NZGP1.2 in the future. Analysis for NZGP1.1 anticipates the following investments in NZGP1.2:

⁴ For NZGP1.1, we propose the approval expiry date to be 31 December 2035 - being three years after the latest expected commissioning date of the NZGP1.1 components if the HVDC Stage 1 investments are deferred.

Table 2: Anticipated investments in NZGP1.2

Anticipated for NZGP1.2 ⁵	
Need	<p>Enable efficient dispatch of new generation and a reliable supply for future demand growth over the interconnected grid through investing in:</p> <p>HVDC investment</p> <p><i>To increase HVDC transfer capacity north from 1200 MW to 1400 MW</i></p> <ul style="list-style-type: none"> • Fourth HVDC Cook Strait cable. <p>CNI investment</p> <p><i>To increase transfer capacity north from Bunnythorpe</i></p>
What is likely to be included in NZGP1.2	<ul style="list-style-type: none"> • Duplex the 220kV Bunnythorpe-Tokaanu A and B lines • TTU the 220kV Bunnythorpe-Wairakei A line; or • Build a new line north of Bunnythorpe • Reconductor the 220 kV Brunswick-Stratford A line. <p>Wairakei investment</p> <p><i>To increase Wairakei Ring transmission capacity under typical operating conditions:</i></p> <ul style="list-style-type: none"> • New or enhanced Wairakei-Whakamaru line.

1.6.2 Project outcomes

This MCP covers investment in projects with specific physical outputs in NZGP1.1 ('projects'). We are seeking approval for measures that will release more capacity from existing grid assets. These improvements can typically be deployed in a shorter timeframe than new assets and provide prompt market benefits and certainty for new electricity consumers and generation developers.

1.6.2.1 HVDC availability and capacity

The role of the HVDC in Aotearoa New Zealand's electricity system is changing. Originally installed to transfer South Island hydro to the North Island it is becoming a critical component in security of supply for both the North and South Islands. As thermal generation in the North Island closes, South Island hydro becomes more important for the North Island in terms of both energy supply and balancing intermittent generation. Additionally, as South Island process heat applications transition away from coal fuel, South Island electricity demand will increase significantly, becoming more vulnerable to dry hydrological years.

In this MCP we are seeking funding to increase the average maximum northwards and southwards transfer capacity available from the existing HVDC. The current 'headline' 1200 MW capacity of the HVDC link is often reduced operationally due to outages of ancillary equipment at Haywards, the AC

⁵ We may submit as sub-stages, to ensure timely delivery of projects, given the need dates may vary.

circuits between Haywards and Bunnythorpe and Wellington electricity load. Average north flow capability over the five-year period between 2017-2021 was 1071 MW.⁶

Our proposal includes installation of additional reactive support equipment, which will lift the average north flow capability to close to the 1200 MW north capacity of the HVDC converters themselves. This additional equipment includes a STATCOM and new filter banks.

As demonstrated in our application of the Investment Test, it is also economic to install a fourth Cook Strait cable, further increasing the northwards transfer capability, to 1400 MW. The funding request for that investment is anticipated to be included in our NZGP1.2.

1.6.2.2 Lower North Island voltage and system stability

A general finding of our investigations is that over time, South Island generation will play a more significant part in firming upper North Island intermittent generation. Along with likely interaction between the two regions in dry years, the lower North Island could be seen as through transmission, connecting these two regions. Resilience of the lower North Island transmission grid will be increasingly important and as electricity flows increase it is more likely that voltage issues will arise. Further investigation of voltage stability in the lower North Island is required. As thermal generation becomes unavailable or is decommissioned in the North Island the amount of inertia provided by this generation decreases. At some point, system stability issues may arise. We therefore intend to further investigate system stability in the lower North Island. Our proposal seeks funding to investigate these issues. Any projects resulting from these investigations will be the subject of a separate MCP.

1.6.2.2 Central North Island capacity

Although futures exist where additional Central North Island (CNI) transmission capacity is required, these are somewhat uncertain. Therefore, we propose to enhance existing CNI transmission assets in NZGP1.1. At the same time, we are also seeking funding to prepare for further enhancements to existing assets, including investigating a new line option that may be required in NZGP1.2.

As electricity flows increase through our Bunnythorpe substation near Palmerston North, it increasingly becomes a potential single point of failure risk in our electricity network. Funding in NZGP1.1 will allow us to study this issue further and consider at what point we should diversify electricity flows through Bunnythorpe and potentially establish a new substation in the region.

Resilience will be key in the choice of route for any new line north of Bunnythorpe to connect at or beyond Whakamaru. Resilience consists of the system's ability to lessen the impact of very severe events on electricity supply and to accelerate the recovery of normal operating conditions. While any route which differs from our existing Bunnythorpe to Whakamaru lines will provide geographical diversity, we also need to consider resilience to climate change effects and natural disasters such as volcanic eruptions. Although we have approaches to identifying resilience risks in our investigation into new line routes north of Bunnythorpe, we do not have an adequate methodology for valuing resilience differences. Funding in NZGP1.1 will allow us to develop an appropriate methodology.

1.6.2.4 Wairakei Ring line capacity

Some existing Wairakei Ring lines are near capacity, and our ability to connect new generation without constraints is limited. We have commissioned a device at Atiamuri that more evenly utilises these lines and in addition, we propose to thermally uprate one of these lines as a part of NZGP1.1.

⁶ Note, this measure does not match our annually reported HVDC link availability. The HVDC link includes the HVDC system circuit between Benmore and Haywards – comprising the converter stations at Benmore and Haywards and the HVDC transmission circuit between them – carried on HVDC overhead line and undersea cable, connecting the converter stations. This is because the HVDC link availability measures exclude other HVDC components and HVAC grid assets.

This will increase the electricity flow by a further 25% or 300 MW northwards through the Wairakei Ring.

However, after this work, we anticipate another significant upgrading to an existing line, or a new line altogether, may be required in the region. We have included funding to identify a suitable new line option in this MCP. The upgrading or new line would be included in NZGP1.2.

1.6.2.5 Supporting projects

There are some supporting projects required as well. These are fully described in section 2.1.4, but are listed here for completeness:

- Split the Bunnythorpe-Ongarue 110 kV line
- Implement upgraded protection on 220 kV Huntly-Stratford 1 circuit
- Replace Special Protection Scheme at Tokaanu
- Implement TTU on 220 kV Edgecumbe-Kawerau 3 circuit

1.6.2.5 Preparatory funding

NZGP1.1 includes funding for some investigations related to preparing for projects in Stage 1.2 as preparatory costs.

These investigations will enable Transpower to advance its response to large binary step-changes in generation and demand, should they occur:

- Investigate options for reconductoring either 220kV Brunswick-Stratford line
- Prepare detailed design to duplex 220kV Bunnythorpe-Tokaanu A&B circuits
- Prepare detailed design to TTU 220kV Bunnythorpe-Wairakei A circuits
- Investigate options, routes, and progress design of a new 220 kV line north of Bunnythorpe.
- Develop a methodology for quantifying resilience benefits
- Investigate options, routes, design new/replaced Wairakei- Whakamaru line
- Undertake investigation into lower North Island voltage stability
- Undertake investigation into lower North Island system stability
- Investigate potential benefits and cost of diversifying Bunnythorpe substation

The total cost of these projects is \$10.2 million. In the case of the detailed design costs, these may or may not eventuate into delivery projects, but by undertaking the designs now, we will be in a position to deliver these projects 6-12 months earlier, if they are required.

1.6.3 Timing

We have determined our project timings on the basis of:

- Tiwai closing at the end of 2024 when its current electricity supply contract expires (a prudent assumption)
- the foreseen difficulties of obtaining outages for delivery of these projects
- the lack of flexibility our workforce will have to change workplans at short notice, particularly once the expected ramp-up in electricity demand is underway.

Providing notice of our intention to deliver specified projects at the timings given will also offer confidence to potential users wanting to switch from fossil-fuelled to electricity-based energy and to generation investors.

We have tested the sensitivity of Tiwai negotiating a long-term electricity supply contract and staying until 2034 in our application of the Investment Test. Two variations are reported – one where we proceed with the proposal and one where the fourth Cook Strait cable is deferred until 2034, at which time the existing cables are also replaced. This lowers the cost of the fourth cable because a cable laying ship is only required once. The proposal has a negative net benefit if Tiwai closure is deferred until 2034, unless the fourth cable is also deferred. The latter option would be sensible in such a situation.

For the range of reasons outlined in Section 2.4 we would not look to defer work on the HVDC Stage 1 works, Central North Island lines, or Wairakei Ring lines if Tiwai does not close in 2024.

1.6.3.1 Tiwai closure date sensitivity and timing of HVDC Stage 1

Our analysis assumes the Tiwai aluminium smelter closes at the end of 2024. That appears to be a conservative assumption based on current market information, but nevertheless remains our assumption, as a prudent grid owner. To assist regulatory decision-makers, we have undertaken sensitivity analysis to consider alternative Tiwai closure possibilities:

- Tiwai closes at the end of 2034 (perhaps by negotiating a longer term electricity supply contract) and we defer installation of a fourth Cook Strait cable until 2032/34
- Tiwai closes at the end of 2034 (perhaps by negotiating a longer term electricity supply contract) and we defer installation of the HVDC Stage 1 works and installation of a fourth Cook Strait cable until 2032/34

In the sensitivities, we assume all Cook Strait cables are replaced at once since the existing three are expected to be at end-of-life in 2034. This reduces the cost of the fourth cable considerably, as we only require a cable laying ship once, instead of twice.

The sensitivity results are:

Table 3: Sensitivity of expected net benefit of proposal to Tiwai closure assumption on our preferred option

Tiwai closure option	Expected net market benefit, \$m
Tiwai closes in 2024, Stage 1 in 2027 and 4 th cable in 2027	145
Tiwai closes in 2034, Stage 1 in 2027 and 4 th cable deferred until 2032	66
Tiwai closes in 2034, Stage 1 and fourth cable in 2032	65

As shown, the expected net market benefit is maximised if Tiwai closes in 2024 and we respond to upgrade South Island to North Island transfer capability as soon as possible, possibly by winter 2027.

If Tiwai closure is deferred until 2034, then it is more economic to defer installation of a fourth cable until the existing cables are replaced, nominally in 2032. Not only is capital expenditure deferred, but deferring the need for a cable laying ship until the existing cable are replaced, means the fourth cable can be installed at an incremental cost, much lower than undertaking such an installation on its own.

If Tiwai closure is deferred until 2034, it is still economic to undertake the HVDC Stage 1 works as soon as possible. The reason for this is that, during RCP4, we are planning to undertake life extension works on the Haywards synchronous condensers and the presence of a new STATCOM will lift the overall transfer capability of the HVDC link during that time.

As Table 3 shows, the expected net market benefit of maintaining the HVDC Stage 1 works asap, is marginally higher than if they were deferred. In addition, there is an unquantified benefit in that the grid is more prepared for uncertain futures should the future not unfold as per the EDGS.

A more fulsome description of the analysis undertaken to demonstrate the HVDC Stage 1 works should not be deferred is included in Appendix A of Attachment C to this proposal.

1.6.4 NZGP1.1 P50 costs and Maximum Capex Allowance

The P50 costs for this MCP and the Major Capex Allowance (MCA) we are seeking approval to recover are shown in Table 4. Our costing approach is discussed further in section 5.1.1. The MCA is higher than the P50 because it includes an allowance for some scope uncertainties and Interest During Construction costs and adds inflation to the P50 cost estimate.

Table 4: Estimated P50 and MCA costs (\$m) of NZGP1.1 projects

Staged project	Purpose	Project outputs	P50	MCA	Estimated commissioning
HVDC WORKS⁷					
HVDC	Stage 1	Install reactive plant, filter banks, associated equipment	84.4	103.1	2027
			84.4	103.1	
CNI WORKS					
CNI	Stage 1	Install VLR and TTU 220 kV Tokaanu-Whakamaru A&B circuits	45.5	51.8	2025
CNI	Stage 1	Install duplex conductors on 220 kV Tokaanu-Whakamaru A&B circuits	94.4	119.4	2028
CNI	Stage 1	Install VLR and TTU 220 kV Bunnythorpe-Tokaanu A&B circuits	68.1	81.6	2026
CNI	Stage 1	Install split on 110 kV Bunnythorpe-Ongarue A line at Ongarue	0.5	0.5	2026
CNI	Stage 1	Install upgraded protection on 220 kV Huntly-Stratford 1 circuit	2.0	2.0	2026
CNI	Stage 1	Replace Special Protection Scheme (SPS) at Tokaanu	1.0	1.0	2026
			211.5	256.2	
WAIRAKEI WORKS					
Wairakei	Stage 1	Install TTU on 220 kV Wairakei-Whakamaru C circuits	10.6	12.0	2025
Wairakei	Stage 1	Install spilt on 110 kV Edgecumbe-Kawerau circuits	0.0	0.0	2025
Wairakei	Stage 1	Install TTU on 220 kV Edgecumbe-Kawerau 3 circuit	10.1	11.4	2025
			20.7	23.3	
PREPARING FOR STAGE 2					
HVDC/CNI	Prepare for future stage(s)	Investigate lower North Island voltage stability	0.3	0.3	2026
HVDC/CNI	Prepare for future stage(s)	Investigate lower North Island system stability	0.3	0.3	2026

⁷ A parallel investigation is underway to assess the need to replace the current HVDC cables as they approach the end of their design life. That project incorporates some investigation work for Stage 2 HVDC works included in the NZGP1.1 MCP, so those costs have not been included here.

Staged project	Purpose	Project outputs	P50	MCA	Estimated commissioning
HVDC/CNI	Prepare for future stage(s)	Investigate potential benefits and cost of diversifying Bunnythorpe substation	0.3	0.3	2026
CNI	Prepare for future stage(s)	Investigate options for reconductoring either 220kV Brunswick-Stratford line	2.0	2.0	2025
CNI	Prepare for future stage(s)	Prepare detailed design to duplex 220kV Bunnythorpe-Tokaanu A&B circuits	1.5	1.5	2025
CNI	Prepare for future stage(s)	Prepare detailed design to TTU 220kV Bunnythorpe-Wairakei A circuits	0.5	0.5	2025
CNI	Prepare for future stage(s)	Investigate, options, routes, progress design of new 220kV line north of Bunnythorpe	3.0	3.0	2026
CNI	Prepare for future stage(s)	Develop a methodology for quantifying resilience benefits	0.3	0.3	2026
Wairakei	Prepare for future stage(s)	Investigate options, routes, design new/replace Wairakei- Whakamaru line	2.0	2.0	2026
			10.2	10.2	
Total			327	393	

1.6.5 Previous consultations

1.6.5.1 Long-list options

We consulted on a long-list of options in August 2021.⁸ That document was:

- a consultation with interested parties on the key assumptions to be used in the investigation
- a draft long-list of options to address the need for investment
- a request for information (RFI) for non-transmission solutions (NTS), which could defer or replace the need for investment in transmission.

Our description of assumptions included detail on the demand and generation scenarios we were intending to use.

1.6.5.2 Feedback on long-list consultation

We received 11 submissions in response to our long-list consultation, from a mixture of lines companies, gen-tailers and generators. These were generally supportive of our aim to enable electrification and renewables. A number of submissions noted the value of considering NTS and incremental investments.

1.6.5.3 Non-transmission solutions

Transpower is committed to exploring the application of non-transmission solutions (NTS) to replace, defer, or enable transmission investment, where economically feasible. Our long-list consultation posed a number of questions regarding how NTS could be incorporated into the development plans created by NZGP1. We received limited responses and, of the responses received, there were none that appeared sufficient to make a significant contribution toward meeting the investment need.

As previously noted, electricity flows over the backbone grid differ considerably to those elsewhere in the grid. We have formed a view that, due to these issues, it is unlikely NTS would be a viable substitute to the projects covered in this MCP. However, NTS may be able to help manage operational risk due to unavailability of grid assets during delivery of the investments included in this proposal and we will explore opportunities for this once they are known.

Our experience to date with contracting NTS for major projects has been hindered by process. We have evaluated NTS as long-list or short-list options, but often several years ahead of the need for such NTS. Our understanding is that, not surprisingly, NTS proponents have been reluctant to commit to services that far ahead. The process we follow is a regulatory requirement, but it was developed when neither ourselves nor the regulator had experience with NTS.

For that reason and to ensure NTS providers are offered a reasonable opportunity, we are proposing this MCP without having fully assessed NTS, but with an undertaking to explore the use of NTS at the relevant time. For NZGP1 this would likely be during the delivery phase of any approved works.

⁸ [NZGP1 long-list consultation document](#)

1.6.5.4 Short-list consultation

Having completed a preliminary application of the Investment Test, and identified a preferred option, we undertook a short-list consultation in July 2022.⁹ That consultation described:

- our variations on MBIE’s current (2019) EDGS
- how we reduced the long-list of options to an intermediate list and then a short-list
- how we used a variation on the “similar” parameter to identify a preferred short-list option
- how our NZGP considerations defined the timing constraints
- our preferred scenario weightings
- our preliminary application of the Investment Test
- our preferred option
- sensitivity analysis
- proposed treatment of NTS in this project.

1.6.5.5 Feedback on short-list consultation

We received 17 short-list consultation responses from generation developers, distribution companies and the Major Electricity Users Group. Generally, these submissions supported our approach to NZGP1. However, some noted that the modelling of our assumptions was complex. Following receipt of submissions, we met with the Major Electricity Users Group to discuss specific questions they had responded on. Other comments were received on the proposed treatment of NTS, noting our position that any feasible options were best signalled and explored closer to the required date, when more specifics were known regarding both timing and capacity.

As a result of uncovering an error in our application of the Investment Test after this consultation, we updated our analysis and changed our preferred option. We consulted on our updated preferred option during August and September 2023, in parallel with consulting on proposed benefits-based charge starting customer allocations as a separate, but related regulatory requirement required by the Transmission Pricing Methodology (TPM).¹⁰

Three submissions were received. Two, in particular, were supportive of our new preferred option and encouraged us to develop capacity in the Wairakei Ring as soon as possible.

A more complete description of our NZGP1.1 consultations, the feedback received, and our views are included in Attachment H.

⁹ [Short-list Consultation Document](#)

¹⁰ [Current TPM Consultations](#)

1.6.5.6 NZGP1 MCP Application Summary

Our December 2022 NZGP1 proposal covered the first stage of the first phase of NZGP – NZGP1.1 and reflected Option 10 (of 18 options) as being preferred. It consisted of:

Table 5: Composition of our original preferred option, Option 10

Option 10	Stage 1 MCP (NZGP1.1)		Possible Stage 2 MCP (NZGP1.2)	
	Project	Expected \$m	Project	Expected \$m
HVDC	Haywards reactive support	84.4	New Cook Strait cable	120
Central North Island (CNI)	TTU ¹¹ /Duplex TKU-WKM A&B TTU BPE-TKU A&B	208.0	Reconductor BRK-SFD A line	75
Wairakei Ring	TTU WRK-WKM C TTU EDG-KAW 220 kV line	20.7		
Supporting projects		3.5		
Preparedness		10.2		

During the investigation we recognised that the varied Electricity Demand and Generation Scenarios (EDGS) we were required to use in our Investment Test analysis, did not cover the full range of future uncertainty in either electricity demand or supply.

Our approach was therefore to include “preparedness” costs in our NZGP1.1 MCP. Preparedness costs are to investigate aspects of further transmission grid requirements that may be needed for future stages of NZGP1, particularly if a future emerged which was not reflected in our varied EDGS. Our intention was to add further stages to the MCP if alternative futures emerged, but to have prepared as much as possible for them, in order to shorten their lead-time.

However, Commission staff pointed out that our interpretation of staging was incorrect. The preferred option must include a technically feasible solution for each of the future stages. Our choice of Option 10 included a defined staging project in the second stage for the HVDC, but not for the CNI lines north of Bunnythorpe, or Wairakei Ring. This meant that any further work on the CNI or Wairakei Ring would need to be the subject of separate MCPs, rather than part of the NZGP1 (staged) MCP.

With that clarification, we reconsidered our proposal and on the assumption that a staged MCP would be administratively less work and more efficient than separate MCPs, we modified our original proposal by issuing an addendum which updated our preferred option to Option 11, as follows:

¹¹ Tactical Thermal Upgrade

Table 6: Composition of preferred option included in our Addendum, Option 11

Option 11		Stage 1 MCP (NZGP1.1)		Possible Stage 2 MCP (NZGP1.2)	
	Project	Expected \$m	Project	Expected \$m	
HVDC	Haywards reactive support	84.4	New Cook Strait cable	120	
CNI	TTU/Duplex TKU-WKM A&B TTU BPE-TKU A&B	208.0	Reconductor BRK-SFD A line	75	
Wairakei Ring	TTU WRK-WKM C TTU EDG-KAW 220 kV line	20.7	New/replaced WRK-WKM line	100	
Supporting projects		3.5			
Stage 2 preparatory		4.0			

Option 11 explicitly included staging projects in the second stage of NZGP1 (NZGP1.2) for the Wairakei Ring. The preparedness funding in our original proposal ensured we could pursue the need for further investment in the Wairakei Ring but using Option 11 meant we could pursue that through a staged, rather than separate, MCP.

Option 14 was the same as Option 11 but also included a second stage for the CNI lines north from Bunnythorpe. It was superior from that point of view, but had a negative expected net benefit, precluding us from preferring that option. Commission staff advised that we could only include preparedness funding for staging projects included in our proposal. We therefore also reduced our preparedness estimate.

Subsequent to issuing that addendum, further questioning from the Commission led us to find an error in our Investment Test analysis. We had overlooked the inclusion of the ongoing costs of maintaining the CNI lines in our Base Case. Correcting this error was significant and meant the net benefits increased between \$100 million and \$150 million on a present value basis for all options. As a result, the expected net benefit for Option 14 was now positive and it became a viable choice as a preferred option. We are therefore updating our proposal again and it now includes staging projects in Stage 2 for each of the HVDC, CNI lines north of Bunnythorpe and Wairakei Ring.

The Commission also pointed out that having a Stage 2 did not bind us to deliver the particular Stage 2 output specified in our Stage 1 MCP. Rather, the inclusion of a Stage 2 investment was really justifying the need for a further investigation at a later time. Any Stage 2 proposal could vary from the original anticipated Stage 2.

Hence, our proposal is now for Option 14 and reinstates the previously titled preparedness funding, but now as Stage 2 preparatory funding.


Table 7: Composition of our updated preferred option, Option 14

Option 14		Stage 1 MCP (NZGP1.1)		Possible Stage 2 MCP (NZGP1.2)	
	Project	Expected \$m	Project	Expected \$m	
HVDC	Haywards reactive support	84.4	New Cook Strait cable	120	
CNI	TTU/Duplex TKU-WKM A&B TTU BPE-TKU A&B	208.0	Reconductor BRK-SFD A line Duplex BPE-TKU A&B TTU BPE-WRK A	75 189 55	
Wairakei Ring	TTU WRK-WKM C TTU EDG-KAW 220 kV line	20.7	New/replaced WRK-WKM line	100	
Supporting projects		3.5			
Stage 2 preparatory		10.2			

1.7 NZGP Phase 2


As already discussed, we will also commence industry engagement on NZGP Phase 2 in 2023. This work will look out to 2050 to identify how the grid backbone and regional interconnections need to develop to provide the required reliability and resilience.

Figure 5: Aotearoa New Zealand transmission grid backbone - the focus of NZGP Phase 2



Overall, the output from the NZGP project is expected to be a long-term transmission plan, or series of plans, showing how we envisage the transmission system could be developed between now and 2050. This plan/s will provide important information for electricity demand and generation investors, giving guidance on future transmission capacity.

2.0 Need for investment



2.1 Existing system

Net Zero Grid Pathways (NZGP) Phase 1 focuses on identifying and investigating potential grid backbone constraints to enable the efficient dispatch of new generation and reliable supply of future demand growth over the interconnected grid, for the period to 2035.

In December 2020, we undertook work to consider the effect on the transmission system of Rio Tinto's announcement to wind-down, and eventually close, the Tiwai Point aluminium smelter (Tiwai).¹² That study identified the most restrictive transmission constraints as occurring on the High Voltage Direct Current (HVDC) link and the North Island 220 kV Alternating Current (AC) network between Bunnythorpe and Whakamaru (referred to as the Central North Island or CNI). Relieving these constraints would provide the highest benefit to consumers. Although the Tiwai closure has now been deferred until at least December 2024, it will still have a significant effect when it does occur, and we need to be as prepared as possible.

In addition, the high number of new generation connection enquiries we are receiving in the vicinity of the Wairakei Ring led us to include this part of the transmission grid in our investigation.

We advised the Commission of this investigation, for a Major Capex Project (staged) covering the first stage in Phase 1 of NZGP (NZGP1.1). Staging the investment will best allow us to take a least-regrets approach and commit to significant expenditure with the maximum amount of certainty. Our investigation covered:

- HVDC capacity
- CNI capacity
- Wairakei Ring capacity.

Our focus has been on investigating thermal constraints on the grid backbone because the lead-time to relieve such constraints is the longest. However, as parts of the grid become more highly loaded and thermal generation closes, voltage and other stability constraints can also emerge. We have started voltage and stability constraint studies separately. This MCP includes a request for funding to assist with external studies to understand whether works to alleviate any such constraints will need to be included as a subsequent MCP.

A general finding of our investigations is that, over time, South Island generation will play a more significant part in firming upper North Island intermittent generation. Along with likely interaction between the two regions in dry years, the lower North Island could be seen as through-transmission, connecting these two regions. Resilience of the lower North Island transmission grid will be increasingly important.

Our investigation considered both a single solution to this issue (bypassing this part of the grid) and a solution that involved upgrading individual parts of the existing grid. We found the latter to be more economic.

The rest of this section comprises a description of the existing HVDC link, the existing 220 kV transmission between Bunnythorpe and Whakamaru and the existing Wairakei Ring system. These descriptions are abbreviated, and more information is available in our Transmission Planning Report.¹³

¹² [Enabling Lower South Island Renewables December 2020](#)

¹³ [Transmission Planning Report 2022](#)

Figure 6: The existing transmission network covered in this MCP



2.1.1 Inter- Island High Voltage Direct Current (HVDC) link

The HVDC link is a key component of the Aotearoa New Zealand transmission network. The existing HVDC link comprises of:

- Two ± 350 kV thyristor bipole converters, Pole 2 and 3, both rated at 700 MW, with converter stations and protection and control systems at our Benmore substation in the South Island and Haywards substation in the North Island.
- Two 350 kV bipolar transmission lines. These comprise a 535 km length from Benmore to Ōraoia/Fighting Bay (on the shore of Cook Strait in the South Island) and a 37 km length from Oteranga Bay (on the shore of Cook Strait in the North Island) to Haywards.
- Three 350 kV, 500 MW, 40 km long undersea cables, with cable terminal stations at Fighting Bay and Oteranga Bay.
- A land electrode at Bog Roy near Benmore in the South Island and a shore electrode at Te Hikowhenua near Haywards in the North Island.
- AC filters to reduce harmonic distortion and provide static reactive support at both Benmore and Haywards.

- Eight synchronous condensers and a STATCOM at Haywards to supplement the dynamic reactive support available from the AC transmission system.

Figure 7: Geographic view of the HVDC Cook Strait link





Figure 8: Simplified schematic of the existing HVDC link



2.1.2 Central North Island (CNI)

The CNI 220 kV transmission system consists of the 220 kV Bunnythorpe–Whakamaru A and B lines and the 220 kV Bunnythorpe–Wairakei A line.

These 220 kV circuits form part of the grid backbone. The lower North Island also has a 110 kV network, which is mainly supplied through the 220/110 kV interconnecting transformers at our Bunnythorpe substation. The direction of power flow through the region is determined by generation, direction of HVDC flow, and demand outside of the region. The CNI region is a main corridor for 220 kV transmission circuits through the North Island. This corridor connects the Central North Island to the:

- Wellington region to the south
- Taranaki region to the west
- Waikato region to the north
- Hawke’s Bay region to the east.

A geographic view of the CNI is shown in Figure 9 and a single line diagram of the CNI and Wairakei Ring regions is shown in Figure 10.

Figure 9: Geographic view of the Central North Island region transmission network






Figure 10: Single Line Diagram of the Central North Island (including Wairakei Ring) transmission network



2.1.3 Wairakei Ring

The Wairakei Ring connects the generation-rich regions of the Central North Island with the high load centres of the upper North Island, Waikato, and Bay of Plenty. The Wairakei Ring consists of two 220 kV transmission lines: the Wairakei–Ohakuri–Atiamuri–Whakamaru A line, which is a single circuit; and the Wairakei–Whakamaru C double circuit line. The geographic layout of these lines is shown in Figure 11 and included in the single line diagram in Figure 10.

Figure 11: Geographic view of the Wairakei Ring



2.1.4 Other North Island constraints

There are other North Island transmission constraints which can limit north flow from Bunnythorpe on the backbone grid, or within the Wairakei Ring region. These constraints are described below. Our analysis includes the work required to relieve these constraints.

2.1.4.1 110 kV constraints

Prior to the 1950s, before the North Island 220 kV grid was built, the national grid consisted of a 110 kV network. When the 220 kV grid was built it was integrated with the existing 110 kV grid. Some parts of this older 110 kV grid now constrain flows on the 220 kV grid.

An example is the Bunnythorpe–Mataroa 110 kV circuit, which is expected to overload in the medium term. As thermal generation in the upper North Island is decommissioned it is likely that generation from the South Island or lower North Island will increase and the Bunnythorpe–Mataroa 110 kV circuit will constrain.

Our investigations indicate this constraint needs to be resolved to allow more generation from Wellington, the Taranaki region, and other areas of the south of the North Island to be exported to the upper North Island. To avoid the CNI proposal being constrained, we are proposing a 110 kV split be implemented concurrently with the CNI proposal.

2.1.4.2 Huntly–Stratford protection limit

As well as the CNI 220 kV lines heading north from Bunnythorpe to Whakamaru, there is also a 220 kV line from Bunnythorpe to Brunswick, which then heads to Stratford and then all the way to Huntly. The Huntly–Stratford portion of this line can become the constraining component in some

circumstances, once the CNI lines are upgraded. The frequency and severity of the constraint depends upon generation within the Taranaki region.

The announced retirement of the Stratford combined cycle generator in 2024 will reduce the frequency of this constraint, but we expect it to still cause constraints at times. Options such as re-building the line and enhancing capacity are possible, although expensive. Our investigations indicate that the thermal rating of the Huntly–Stratford 220 kV circuit is currently limited by a protection relay. If a low-cost project to replace the protection relay is completed, the full thermal capacity of the line becomes available and this will no longer constrain the CNI capacity.

2.1.4.3 Tokaanu Special Protection Scheme (SPS)

The existing Tokaanu SPS monitors the two Tokaanu–Whakamaru circuits and splits the Tokaanu 220 kV bus when it detects the outage of one of the circuits. The scheme results in power flow from Bunnythorpe towards the upper North Island being redistributed to other transmission paths to relieve the loading on the constraining Tokaanu–Whakamaru circuit.

Our investigations indicate that once the Tokaanu–Whakamaru circuits are upgraded, the constraint will shift to the Bunnythorpe–Tokaanu circuits. Upgrading the Tokaanu SPS to also split the Tokaanu 220 kV bus following a Bunnythorpe–Tokaanu circuit outage will have a similar effect of relieving the loading on the remaining Bunnythorpe–Tokaanu circuit. (See Attachment C: 3.5.5 Use of Area Wide and Special Protection and Runback Schemes).

2.1.4.4 Edgecumbe–Kawerau 220 kV line

The Edgecumbe–Kawerau 220 kV circuit is part of a 220 kV corridor that runs from Ohakuri to Atiamuri via Kawerau, Edgecumbe, and Tarukenga. Because this corridor runs in parallel with the Atiamuri–Ohakuri direct circuit, increased north flow through the Wairakei Ring implies increased flow from Kawerau to Edgecumbe.

There are already high power transfers from Kawerau to Edgecumbe, driven by a generation excess in the eastern Bay of Plenty and high load in the western Bay of Plenty. Without a capacity increase on the Edgecumbe–Kawerau 220 kV circuit, higher power transfer through the Wairakei Ring could not be achieved without pre-contingency generation constraints at Kawerau and/or Ohakuri.

A thermal upgrade of the Edgecumbe–Kawerau 220 kV circuit would also enable further generation development in the eastern Bay of Plenty and increase the ability of the grid to supply the growing western Bay of Plenty loads from eastern Bay of Plenty generation.

This thermal upgrading is required to make full use of the proposed Wairakei Ring upgrades.

2.1.4.5 Brunswick–Stratford 220 kV

The Brunswick–Stratford section of the Bunnythorpe to Huntly 220 kV route can also constrain flows north from Bunnythorpe.

This part of the route consists of two lines, with one line nearing end of life. A plan has yet to be formulated for the two Brunswick–Stratford lines, with options ranging from replacing the old line to dismantling the old line and upgrading the newer line.

In our analysis we assume the Brunswick–Stratford constraint is relieved by 2030.

2.2 Overview of the need for investigation and investment

We have investigated how best to enable the efficient dispatch of new generation and reliable supply of future demand growth over the interconnected grid.

As Aotearoa New Zealand pursues its goal of being net zero carbon by 2050, electrification will increase electricity demand and new renewable generation will be built. This is irrespective of the timing of the Tiwai Point smelter closure. As this occurs, we expect a number of constraints will emerge on the transmission grid between the top of the South Island and Whakamaru (including the Wairakei Ring).

Relieving these constraints would provide confidence to generation investors that new generation could be economically dispatched and ensure the generation investment market remains competitive.

We could build a new connection between these parts of the network or enhance parts of the existing network – the HVDC, our CNI 220 kV network and the Wairakei Ring.

Figure 12: Initiatives being investigated in NZGP1



2.2.1 HVDC capacity

The nominal rating of the Pole 2 and Pole 3 HVDC converters is 700 MW each. However, we only have three 500 MW cables across Cook Strait. Two are connected to Pole 3 and one is connected to Pole 2. This means the nominal end-to-end capacity of Pole 2 is limited to 500 MW and the combined HVDC capacity is limited to 1200 MW.

Historically, the HVDC was installed to transfer electricity produced from South Island hydro generation to the North Island. The North Island had adequate thermal generation to be self-sufficient in terms of electricity supply, so North Island demand was not reliant on when electricity from the south was dispatched north. This is changing as South Island supply is more critical in meeting North Island peaks with the retirement of thermal generation and inability to rely on wind and solar generation to meet peak demands.

In total, the HVDC link between the North and South Islands has a capacity of up to 1000 MW in balanced 500/500 MW bipole operation and up to 1200 MW¹⁴ in unbalanced 500/700 MW bipole operation. The ability to run in unbalanced mode depends upon the availability of instantaneous reserves from the electricity market, as this mode requires more reserves to be procured. These are north flow capacities, with south flow limited to 850 MW.

Other factors also affect the north flow capacity, in particular the availability of ancillary equipment at Haywards and surrounding AC transmission. There are eight synchronous condensers at Haywards which provide voltage support to the HVDC. These large mechanical rotating machines require frequent maintenance. If any machine is out of service for maintenance, the HVDC north flow limit is reduced. Similarly, the AC lines between Haywards and Bunnythorpe are all required. These lines are taken out of service from time-to-time for maintenance, which also reduces the north flow limit. A recent historical analysis found that, over the last five years, average north flow capability has been 1071 MW when taking account of available ancillary equipment and AC line outages.

Our studies indicate that the role of the HVDC link in the Aotearoa New Zealand power system is likely to change. Wind and solar generation is intermittent. Electricity from wind generation is only available if the wind is blowing and electricity from solar generation is only available if the sun is shining. Other forms of generation are required to “firm” such intermittent generation. Currently, as wind and solar generation grows in the North Island, it can be firmed by hydro generation in the North Island and peaking gas fired generation. However, as gas fired generation is closed and more North Island wind and solar generation is built, it will start to be firmed using South Island hydro generation. Eventually South Island hydro will be critical to real-time supply of North Island load and availability of the HVDC will play a critical role.

Our investigation considered not only options for increasing HVDC Cook Strait capacity, but also options to lift the availability of that capacity.

¹⁴ Although maximum transfer capability of the HVDC assets is continuously available (not withstanding outages), the maximum energy transfer achieved at any point in time is dependent on market energy and reserve offers, and the capacity of the surrounding AC networks in the North and South Islands to supply regional loads and support both AC and HVDC energy transfer requirements.

2.2.2 CNI 220 kV

North flow transmission through the CNI region is currently close to being constrained at times. If any significant new generation is developed south of Bunnythorpe, we would likely see significant constraints. Tiwai Point smelter closure or further new wind generation projects in the lower North Island, for instance, would result in significant constraints.

Previous analysis indicates that the two Tokaanu–Whakamaru 220 kV circuits can constrain north flow through the CNI region in various scenarios. If constraints on these circuits are removed via upgrade work, then the two Bunnythorpe–Tokaanu 220 kV circuits would become the limiting constraint.

Our investigation considered options to increase flows through the CNI, including thermal upgrades of existing lines and building a new line altogether.

2.2.3 HVDC and CNI timing

The HVDC and CNI constraints will bind frequently following a Tiwai exit, which could happen as early as 2024. The constraints should therefore be alleviated as soon as reasonably practicable to ensure lower South Island renewable generation can be utilised in the event of a 2024 Tiwai exit. Considering investment approval and project execution timelines, we consider the earliest this work could be completed is 2027 (for the first stage of the HVDC investment) and 2028 (for the first stage of the CNI investment). Another timing consideration for the CNI investment is that the longer the work is delayed, the more difficult it will be to secure the necessary grid outages without compromising reliability (owing to load growth). If the CNI investment is delayed for too long, some outages may become infeasible.

2.2.4 Wairakei Ring

The capacity of the Wairakei–Whakamaru line and Wairakei–Ohakuri–Atiamuri–Whakamaru line may cause a transmission constraint during high generation in the Wairakei Ring, eastern Bay of Plenty or Hawke’s Bay areas. This constraint would be exacerbated if there is a reduction in industrial load in the Bay of Plenty region, or if additional generation is developed around the Wairakei, Bay of Plenty, or Hawke’s Bay regions. High through-transmission on the CNI lines north to Whakamaru can also exacerbate the Wairakei Ring constraint, but to a lesser extent.

Thermal uprating is possible on the Wairakei–Whakamaru line, but not on the Wairakei–Ohakuri–Atiamuri–Whakamaru line. A series reactor has been installed on the Wairakei–Ohakuri–Atiamuri–Whakamaru line (to balance flows on the Wairakei Ring circuits).

Our investigation focussed on thermal uprating of the Wairakei–Whakamaru line, duplexing the single circuit Wairakei–Ohakuri–Atiamuri–Whakamaru line and new line options.

2.2.5 Wairakei timing

The Wairakei constraints will bind frequently if some or all of the large volume of current enquiries for the connection of new renewable generation in the Wairakei region result in new generation projects. The constraints should therefore be alleviated as soon as reasonably practicable to enable new renewable generation projects in the region. Considering investment approval and project execution timelines, we consider the earliest the first stage of this work could be completed is 2025.

2.3 Relevant asset condition issues

2.3.1 Condition of Pole 2 Equipment and HVDC Cables

The Pole 2 converters and three Cook Strait cables were commissioned in 1991 and have performed very well to date. The converter transformers and valves are generally in good order and another 25 years of service is expected if critical items are refurbished at the half-life point in their lifecycle, which is now. Preparations are in progress to complete these refurbishments during the remainder of Regulatory Control Period 3 (RCP3) and RCP4.

Pole 2 control systems, which had a shorter lifecycle due to obsolescence, were replaced during the Pole 3 project in 2012. Critical Valve Base Electronics equipment (part of the control system) not able to be replaced during the Pole 3 project was replaced in 2020 along with all snubber capacitor assemblies within the valves. With these refurbishments, we expect Pole 2 will last well beyond 2040 and for the purposes of this analysis, we have assumed an expected life to 2050.

The three Cook Strait submarine cables which have a 40-year design life, are anticipated to reach the end of their life in approximately 2032.

A study is underway into the replacement of the existing cables. This investigation has demonstrated that installation of a fourth cable, to lift HVDC transfer north capacity to 1400 MW, is economic. We have evaluated the cost based on separate installation of a fourth cable. However, this work could be undertaken at the same time as replacing the others. We are therefore examining whether to bring replacement of the other cables forward or defer installation of a fourth cable until the others reach end-of-life. In all circumstances, how the replacement of the existing cables will be funded will be agreed separately with the Commission.

2.3.2 Condition of CNI and Wairakei Ring lines

The most relevant condition issue for both the CNI and Wairakei Ring sections of the backbone grid are the condition of the conductors and when they would otherwise be replaced.

In some options future maintenance (conductor replacement) may be avoided. The following table summarises the assumptions used in our NZGP1 analysis.

Table 8: NZGP1 CNI and Wairakei Ring 220kV line end-of-life assumptions

Line	End of life range	NZGP1 end of life assumption
Bunnythorpe–Whakamaru A	2034 – 2049	2042
Bunnythorpe–Whakamaru B	2034 – 2050	2042
Bunnythorpe–Wairakei A	2050 -2076	>2050
Wairakei–Whakamaru A	2037 – 2070	>2050
Wairakei–Whakamaru C	2109 - 2137	>2050

2.3.3 Good electricity industry practice

The Capital Expenditure Input Methodology (Capex IM) requires Transpower to comply with Good Electricity Industry Practice (GEIP) and as such we have ensured that the planning and performance standards used to determine the investment options reflect GEIP. The requirement is specified in the Electricity Industry Participation Code as:

“the exercise of that degree of skill, diligence, prudence, foresight and economic management, as determined by reference to good international practice, which would reasonably be expected from a skilled and experienced asset owner engaged in the management of a transmission network under conditions comparable to those applicable to the grid consistent with applicable law, safety and environmental protection. The determination is to take into account factors such as the relative size, duty, age and technological status of the relevant transmission network and the applicable law.”

2.4 Key factors affecting our application

2.4.1 Significant uncertainty

To model possible economic benefits from our investments, we require plausible scenarios of New Zealand’s future electricity supply and demand. These scenarios must be consistent with New Zealand achieving net zero carbon by 2050. While we started from MBIE’s 2019 Electricity Demand and Generation Scenarios (EDGS), we identified an unusually large number of possible futures, due to the large number of significant uncertainties.

For instance:

- Rio Tinto has announced that it intends to wind-down and eventually close the Tiwai Point aluminium smelter. Tiwai uses a considerable percentage of South Island hydro generation. There is uncertainty as to the future timing of any wind down.
- Electrifying Transport. How quickly will Aotearoa New Zealand adopt electric vehicles (EVs) and replace our fossil fuel fleet? Will heavy vehicles also become electric or use an alternative fuel? How will consumers and business charge these vehicles?
- Process heat electrification. Electricity is the likely fuel for low temperature process heat applications, but will electricity, biomass or some other fuel dominate high-temperature applications?
- Grid-scale wind and solar generation costs are forecast to drop over time. Currently there is cost parity between on shore wind and solar generation installation. Will this persist?
- Widespread battery storage could significantly change the services required from both electricity transmission and distribution. Will storage costs fall to the point where batteries are widespread?
- Aotearoa New Zealand has world class offshore wind resources, and some locations are ideally suited for offshore wind development. Will that occur?
- The Huntly coal-powered Rankine units currently provide the majority of Aotearoa New Zealand's back-up electricity supply in the event of a dry hydrological year. Assuming they are closed, what will replace them for dry year reserve?

Each of these uncertainties is significant for transmission grid planning, so we developed a range of future scenarios and combined them into a matrix. For this investigation we developed a matrix of 30 scenarios. Because it is infeasible to analyse so many scenarios and, from a regulatory perspective, it would be difficult to justify our choice of sampled scenarios from this matrix, we reverted to developing variations of the five Electricity Demand and Generation Scenarios (EDGS).

2.4.2 A least regrets approach

A high level of uncertainty increases the risk of under or over-building transmission capacity. Scenario analysis helps to identify investments that produce the highest net benefits across the range of scenarios. However, for NZGP we have also applied a least regrets approach. This is where we undertake investment for a more certain level of need but prepare for adding more capacity.

Pursuing least regret options allows us to provide the capacity as it is needed, reducing the risk of late investment while protecting consumers from investing too early in significantly more expensive projects such as building new transmission lines. This approach is commonly used on overseas networks, maintaining flexibility of when to proceed with further transmission grid capacity enhancements as the future unfolds.

2.4.3 Timeliness and preparatory costs

Alongside a least regrets approach, it is important that we prepare for adding more capacity. There are significant lead times for a large build. For example, some detailed design investigations can take up to two years. Undertaking this design work early allows us to accelerate the build when we have better certainty around the timing of the investment.

Preparing for uncertain futures does incur a cost and there is a risk that some plans may not be used, but the expected costs are relatively small compared to the benefits. The costs will vary from project to project but are expected to be in the range of <1 per cent up to 10 per cent of the delivered benefit. We consider that undertaking early design work is a prudent and efficient approach.


2.4.4 Managing our workforce

Part of following good electricity industry practice, and being a prudent and efficient operator, is managing our resources. If we do this, we can deliver major capex projects alongside our ongoing grid replacement and refurbishment and customer work.

Our workforce consists of specialised teams of highly trained people. It often takes many years to develop the necessary skills to safely undertake work on transmission assets.

The national peak demand forecast compiled for our 2022 Transmission Planning Report, as shown in Figure 13, clearly shows a ramp-up in demand in the next 15 years. This will be matched by a similar or even greater ramp-up in new generation connections. This is an expected feature of Aotearoa New Zealand’s electrification endeavours and creates workforce challenges.

Figure 13: Transmission Planning Report 2022 peak demand forecast



Our workforce will be stretched during the expected ramp-up. Planning will be important, and we expect workforce plans to cover longer time periods than usual. Our flexibility to change plans will be limited and changing plans at short notice may result in other work not being undertaken, as rescheduling may be impractical.

To ensure that capacity is available when it is required, the most economical approach may be undertaking work slightly ahead of its specific need date.

2.4.5 Transmission outages

Most upgrade work on the transmission grid requires transmission outages. If a transmission line is thermally upgraded, for instance, the line needs to be de-energised (turned off) while the necessary work is undertaken. The time while a line is de-energised is called an outage. Such outages are usually scheduled in periods of time (windows) to minimise disruption to the electricity market. Windows can be as short as several hours, or up to several weeks, depending upon the work required.

As demand on the transmission grid increases, it becomes more difficult to find outage windows which do not significantly impact the electricity market. Longer outage windows become infeasible and as a result, some major transmission upgrades would need to be delivered using short outage windows over several years.

Finding suitable outage windows for transmission upgrades is particularly difficult on the backbone of the grid, as electricity flows tend to be more constant than in some regional parts of the grid where flows are more highly correlated with electricity demand.


The need for transmission outages to undertake upgrade work can ultimately determine when upgrades need to occur. In some instances, if an upgrade is required, it may need to be undertaken several years ahead of the upgrade need, because otherwise the required outages would have an unacceptable impact on market participants or would be infeasible due to insufficient generation in the constrained region during the outage.

2.4.6 Approval expiry date

The Capex IM requires a MCP application to include an approval expiry date. This is the date beyond which the Commission's approval becomes null and void. Our interpretation of the Capex IM is that the approval expiry date should be set at a point in time beyond which the approval may not be relevant anymore and the proposed investments may not be appropriate.

For NZGP1.1, we propose the approval expiry date to be 31 December 2035 - being three years after the latest expected commissioning date of the NZGP1.1 components if the HVDC Stage 1 investments are deferred.

3.0 Regulatory process for the approval of investments expected to cost more than \$20 million



3.1 Regulatory process

This investigation has determined that enhancing the service provision of parts of the existing grid is economic. The cost will exceed \$20 million. Approval of this MCP by the Commission will allow Transpower to recover the costs of the proposal from transmission customers. This would occur either as operating expenditure (should the investment be a recoverable cost), or as investment on our regulated asset base. The costs (opex, and the return of and on the capex) will be recovered through the Transmission Pricing Methodology (TPM).

On 12 April 2022, the Electricity Authority announced its decision to adopt a new TPM. Transpower implemented the new TPM into prices that came into effect on 1 April 2023.

A key component of the new TPM is a benefit-based charge (BBC). This is designed to recover the costs of seven historical grid investments and other major grid investments made post-2019. The BBC allocates the cost of those grid investments to transmission customers. This occurs broadly in proportion to customers' positive net private benefits from those investments (as expected at the time of setting the charge). For any investment over the base capex threshold in the Transpower Capex IM with a capital cost of more than \$20 million (a 'high-value investment') one of the TPMs standard methods would be used to calculate customer allocations.

3.2 Transpower process

We began this investigation in 2020, notifying the Commission of our intent, in a letter dated 23 July 2021.

The process we have used for this investigation is consistent with the requirements of the Commission's Capex IM. We have, however, consulted more widely than required.

The Capex IM requires that we use the most recent Electricity Demand and Generation Scenarios (EDGS) in our investigation, or reasonable variations of those scenarios. We identified several important changes since the last EDGS were published and conducted a review with a view to developing more up-to-date variations. The review involved forming a panel of external (to Transpower) experts to advise us on potential variations and two online panel sessions.¹⁵ This enabled us to develop a set of variations (published in December 2020) for consultation.¹⁶ Further explanation of the EDGS is available in Appendix A of Attachment C.

After feedback on that consultation, we undertook further consultation to help us develop our generation scenario variations. We published a long-list consultation document for NZGP1.1 in August 2021 and a final version of the scenarios in December 2021.

We carried out additional analysis to reduce the long-list of options to address the need to a short-list. We then applied the Investment Test to that short-list of options. This document describes our application of the Investment Test and the resulting stage 1 of Phase 1 of NZGP.

In response to our previous consultations, this document departs to some extent from our previous MCP applications in relation to relevant demand and generation scenarios. We summarise our final scenario variations only, with a reference to our December 2021 document for complete detail.

¹⁵ [Consultation on EDGS 2019 Variations to develop generation scenarios](#) | Transpower

¹⁶ [TP Net Zero Grid Pathways – Consultation - Final](#) 13 Jan'21.pdf (transpower.co.nz)

Although different, this approach is still consistent with the requirements of section 13 of Schedule 1 of the Capex IM.

3.3 Treatment of non-transmission solutions

We have departed from our traditional approach to the consideration of non-transmission solutions (NTS).

Previously, we issued an RFI for NTS with our long-list consultation and followed up on any interest during our analysis, reporting on the outcome as a part of our Investment Test application.


We issued a high level RFI with this long-list consultation and received some responses. However, interest from proponents was mostly limited to supporting the overall concept of NTS, rather than offering specific projects or technologies to replace or defer transmission options.

Electricity flows over the backbone grid are determined by the dispatch of generation rather than local demand peaks and troughs. As a result, peak flows driving our investments, are difficult to predict. In the future, when North Island thermal generation is retired, peak usage may become more aligned with the strength of the wind and cloud cover, which is even less predictable. Due to these factors, we consider NTS are unlikely to provide a viable substitute for transmission on the backbone grid.

Despite this, NTS may be able to help manage operational risk caused by the unavailability of grid assets during delivery of the investments included in this proposal. We will explore opportunities for this once the risks are clear.

Our experience to date with contracting NTS for major projects has been hindered by process. We have evaluated NTS as long-list or short-list options. This has, however, often occurred several years ahead of the need for such NTS. Our understanding is that, unsurprisingly, NTS proponents are reluctant to commit to services that far ahead and engagement with such proponents has been limited. The process we follow is a regulatory requirement, but it was developed when neither ourselves nor the regulator had experience with NTS. The process we are following in this MCP is more likely to appeal to proponents of NTS.

4.0 Long and Short-list of options



4.1 Options

Our long-list of options comprises components that:

- bypass the existing grid altogether
- increase transfer capacity across the inter-island HVDC link
- increase capacity on the backbone grid north of Bunnythorpe
- increase capacity in the Wairakei Ring region
- could be included in the Stage 1 MCP, or in future MCPs.

The long-list includes potential components to meet the need, irrespective of perceived cost or practicality. These components are detailed in Attachment C and are not described in detail here. They comprise components as varied as a new HVDC link between Haywards and Whakamaru, undersea cables from near Nelson to Taranaki and undergrounding our transmission lines between Bunnythorpe and Whakamaru.

The long-list is lengthy, and we use a range of approaches to reduce the long-list to a short-list for Investment Test analysis. Initially, we have applied high-level short-listing criteria to sieve out options which are infeasible and/or clearly uneconomic.

We then combined the remaining long-list of components into (short-list) development plan options which meet the overall need.

4.1.1 Shortlisting criteria

We evaluated our long-list of options using the following high-level screening criteria. The screening criteria were used to eliminate options inappropriate for consideration in development plans. The criteria are:

1. Fit for purpose
 - The design will meet current and forecast energy demand
 - The extent to which the option resolves the relevant issue
2. Technically feasible
 - Complexity of solution
 - Reliability, availability and maintainability of the solution
 - Future flexibility – fit with long term strategy for the grid
 - Ideally the design can be staged and/or has flexibility to preserve options for future changes
3. Practical to implement
 - It must be possible to implement the solution by the required dates
 - Implementation risks, including the likelihood of obtaining any necessary outages and potential delays due to property and environmental issues, are manageable
4. Good electricity industry practice (GEIP)
 - Ensures safety
 - Consistent with good international practice
 - Ensures environmental protection
 - Accounts for relative size, duty, age and technological status
 - Technology risks
5. Provides system security

- Improves resilience of the power system
 - Has benefits for system operation (e.g., controllability)
 - Improves voltage stability (e.g., has modulation features or improves system stability)
6. Indicative cost
- Whether an option will clearly be more expensive than another option with similar or greater benefits.

4.1.2 Intermediate development plan options

In general, development plan options include combinations of components, commissioned at different times. For instance, where a component has a long lead-time e.g., building a new transmission line, we may also include a short-term, or “tactical” option to enhance capacity until such time as a new line can be commissioned.

The long-lists of components and subsequent development plans were developed differently in the three different staging project investigations – HVDC, CNI and Wairakei Ring.

For application of the Investment Test, development plans for each of the three areas (HVDC, CNI and Wairakei Ring) were combined into overall development plans, i.e., an HVDC development plan option was combined with a CNI development plan option and a Wairakei Ring development plan option.

Initially, there were 2 x HVDC, 11 x CNI and 7 x Wairakei Ring development plan options, giving 154 development plan options in total. Typically, we evaluate three to six options using the Investment Test. To undertake the Investment Test for 154 options over the five varied EDGS would require more than 700 individual analyses. The benefits for each option are identified using SDDP, a proprietary load-flow modelling tool, which takes up to 24 hours to evaluate an individual analysis. This level of analysis was infeasible.

To reduce this so-called Intermediate short-list of development plan options to a more practicable number, we undertook limited economic analysis to identify a preferred option for upgrading the existing grid for the HVDC/CNI and Wairakei Ring. We then applied our NZGP considerations to identify three options for each of the CNI and Wairakei Ring, which resulted in a manageable short-list to which we could apply the Investment Test.

Table 9: List of Intermediate development plan options

List of intermediate development plan options ¹⁷									
Base Case									
Option 0	Do not enhance existing grid								
Options to meet the overall need and bypass the existing grid									
	New North Island HVDC	New inter-island HVDC							
Option B1	✓								
Option B2		✓							
Options to enhance HVDC capability									
	New HAY reactive support 1200MW	4 th Cook Strait cable 1400MW							
Option H1	✓								
Option H2	✓	✓							
Options to enhance CNI capacity									
	BPE-ONG split	HLY-SFD protect upgrade	BRK-SFD enhance	TTU TKU-WKM	TTU BPE-TKU	TTU BPE-WRK	Duplex TKU-WKM	Duplex BPE-TKU	New line north BPE
Option C1	✓	✓	✓	✓					
Option C2	✓	✓	✓	✓	✓				
Option C3	✓	✓	✓	✓		✓			
Option C4	✓	✓	✓	✓	✓	✓			
Option C5	✓	✓	✓	✓			✓		
Option C6	✓	✓	✓	✓	✓		✓		
Option C7	✓	✓	✓	✓	✓		✓	✓	
Option C8	✓	✓	✓	✓	✓	✓	✓	✓	
Option C9	✓	✓	✓	✓	✓				✓
Option C10	✓	✓	✓	✓	✓	✓			✓
Option C11	✓	✓	✓	✓	✓		✓	✓	✓
Options to enhance WRK capacity									
	EDG-KAW split	TTU WRK-WKM C line	Duplex WRK-WKM A line	TTU EDG-KAW	Replace WRK-WKM A Option D5A	Replace WRK-WKM A Option D7	New WRK-WKM D line	WRK sub equip	
Option W1	✓	✓		✓					
Option W2	✓	✓	✓						
Option W3	✓	✓	✓	✓					
Option W4	✓	✓		✓	✓				
Option W5	✓			✓		✓		✓	
Option W6	✓	✓		✓		✓			
Option W7	✓			✓			✓	✓	

¹⁷ Refer to Attachment C for a more detailed explanation of these options

4.1.3 Evaluating the intermediate list of HVDC and CNI options

We note our intermediate list analysis, which was undertaken using an Investment Test-like approach, resulted in us implementing a “similar” definition approach (as defined in the Capex IM (Schedule D, clause D1(2)(a)) to differentiate between options. The similar parameter recognises that uncertainty can, under some prescribed circumstances, lead to more than one option passing the Investment Test.

Our approach and results are described in detail in Attachment C, with the outcome being the short-list of options in Table 10. In summary, we varied the “similar” parameter from 10 per cent, as outlined in the Capex IM, to 15 per cent. Varying this parameter is allowed for in the Capex IM, provided Transpower convinces the Commission such a variation is reasonable. In this analysis, we limited our choice of scenarios to five varied EDGS. However, we originally identified more than five scenarios would be required to fully describe future uncertainty, particularly around generation expansion. This leads us to believe that the uncertainty in benefits is higher than normal and we consider 15 per cent to be a reasonable setting in this analysis.

Having established that options are “similar”, unquantified benefits can then be used to distinguish between options. We concluded that, for the HVDC/CNI, similar option C6 would add significantly more capacity than option C1 and provide unquantified competition benefits. These factors made option C6 preferred over option C1, and option C6 progressed to the short-list.

4.1.4 Evaluating the intermediate list of Wairakei Ring options

Our approach to evaluating the intermediate list of Wairakei Ring options and the results from applying this approach are described in detail in Attachment C. The outcome is the short-list of options in Table 10. The intermediate list from Table 9 comprised seven options to enhance the Wairakei Ring capacity, ranging from tactical investments, such as splitting the Edgcumbe–Kawerau bus, through to a new Wairakei to Whakamaru D Line.

We undertook a simplified analysis, as with the CNI, to reduce the intermediate list to a short-list for Investment Test analysis. These three options comprised a combination of both tactical and new line options.

4.2 Short-listed development plan options

Following the above evaluations, we were left with the following list of short-listed development plan options, including two which bypass the existing grid altogether.

Table 10: Short list development plan options matrix

List of shortlisted development plan options									
Base Case									
Option 0	Do not enhance existing grid								
Options to meet the overall need and bypass the existing grid									
	New North Island HVDC	New inter-island HVDC							
Option B1	✓								
Option B2		✓							
Options to enhance HVDC capability									
	New HAY reactive support 1200MW	4 th Cook Strait cable 1400MW							
Option H1	✓								
Option H2	✓	✓							
Options to enhance CNI capacity									
	BPE-ONG split	HLY-SFD protect upgrade	BRK-SFD enhance	TTU TKU-WKM	TTU BPE-TKU	TTU BPE-WRK	Duplex TKU-WKM	Duplex BPE-TKU	New line north BPE
Option C6	✓	✓	✓	✓	✓		✓		
Option C8	✓	✓	✓	✓	✓	✓	✓	✓	
Option C9	✓	✓	✓	✓	✓				✓
Options to enhance WRK capacity									
	EDG-KAW split	TTU WRK-WKM C line	Duplex WRK-WKM A line	TTU EDG-KAW	Replace WRK-WKM A plan A	Replace WRK-WKM A plan B	New WRK-WKM D line	WRK sub equip	
Option W1	✓	✓		✓					
Option W4	✓	✓		✓	✓				
Option W7	✓			✓			✓	✓	

4.2.1 Bypassing the existing grid

We undertook a high-level economic analysis to consider whether options B1 and/or B2 should be carried forward for Investment Test analysis. Both these options include building new HVDC links between different parts of the grid.

In option B1 (the new North Island option), we retain the existing inter-island HVDC link, but build a new line from Haywards to Whakamaru. This would bypass the existing Haywards to Whakamaru AC

lines, avoiding the need to upgrade these lines. Being a separate line route, it would provide more resilience to the electricity system. Our high-level cost estimate for this option is \$2 billion.

In option B2 (the new inter-island link option), a new HVDC line is built in the South Island, possibly to somewhere in the Nelson region, a new set of undersea cables is laid to the North Island, possibly in the Taranaki region, and a new HVDC line is built in the North Island, possibly all the way to Huntly. New HVDC converters are also installed in both the North and South Islands. We consider this may provide the most resilient electricity system overall, at a high-level estimated cost of \$4 billion.

Neither of these options improve capacity on the Wairakei Ring and we would need to undertake our proposed works for the Wairakei Ring as well.

Our similarly high-level cost estimate to upgrade the existing AC grid (including a new line north of Bunnythorpe) is \$1.2 billion, which includes our proposed works for the Wairakei Ring.

Table 11: Options to bypass the existing grid

Option	High level cost, \$b	Comments
Upgrade existing grid - preferred	\$1.2	Includes all Stage 1 and 2 costs
New North Island HVDC Option	\$2.0	Requires new HVDC line from HAY to WKM plus new HVDC converters at WKM
New inter-island HVDC Option	\$4.0	Requires new HVDC lines in North and South Island plus new HVDC converters in South Island and HLY, plus new inter-island cables

Although we have not attempted to quantify the resiliency benefits of options B1 and B2, in our view they are unlikely to outweigh the extra cost and this analysis is sufficient to demonstrate that upgrading the existing grid is more economic. Neither option B1 nor B2 is carried forward for Investment Test analysis.

The other options passed our initial high-level economic analysis and application of our strategic considerations, leaves a short-list comprising:

- two HVDC options
- three CNI options
- three Wairakei Ring options.


4.2.2 Final short-list of options for Investment Test analysis

We evaluated 18 short-list options in the Investment Test, being all combinations of the following:

Table 12: Shortlist development options

List of shortlisted development plan options									
Base Case									
Option 0	Do not enhance existing grid								
Options to enhance HVDC capability									
	New HAY reactive support 1200MW	4 th Cook Strait cable 1400MW							
Option H1	✓								
Option H2	✓	✓							
Options to enhance CNI capacity									
	BPE-ONG split	HLY-SFD protect upgrade	BRK-SFD enhance	TTU TKU-WKM	TTU BPE-TKU	TTU BPE-WRK	Duplex TKU-WKM	Duplex BPE-TKU	New line north BPE
Option C6	✓	✓	✓	✓	✓		✓		
Option C8	✓	✓	✓	✓	✓	✓	✓	✓	
Option C9	✓	✓	✓	✓	✓				✓
Options to enhance WRK capacity									
	EDG-KAW split	TTU WRK-WKM C line	Duplex WRK-WKM A line	TTU EDG-KAW	Replace WRK-WKM A plan A	Replace WRK-WKM A plan B	New WRK-WKM D line	WRK sub equip	
Option W1	✓	✓		✓					
Option W4	✓	✓		✓	✓				
Option W7	✓			✓			✓	✓	

5.0 Options analysis



5.1 Investment Test approach

Having received mostly supportive feedback for our preferred option, we finalised our short-list of options. Our consideration included delivery timing, which reflects the availability of third parties to undertake the construction works while continuing to fulfil obligations to complete other Transpower work.

We engaged further with our Engineering Consultant partners and further refined the scope of work based on our development plans and further refined the pricing for our construction options.

We then assessed the short-list of development plans using the Investment Test, as prescribed in Schedule D of the Capex IM.¹⁸

Sensitivity analysis was undertaken to test the robustness of the Investment Test result. The remainder of this section provides details on our application of the Investment Test and key inputs. This MCP application to the Commission reflects the results.

Indicative covered costs and indicative benefit-based regional allocations under the new TPM for the proposal have been calculated and a consultation paper can be found here¹⁹. More information on how the TPM, EDGS, and investment test parameters affect the Investment Test is contained in Appendix A of Attachment C.

5.1.1 Project costs

Project costs are costs reasonably incurred by Transpower in undertaking a major capex project. These include, but are not necessarily limited to:

- Capital expenditure, including capital expenditure for land purchased for an option
- Costs payable to a third party for testing
- Costs payable for commissioning of assets
- Operating, maintenance, and dismantling costs
- Compliance costs relating to applicable legislation and administrative requirements.

Since the short-list consultation, all projects have been costed. This excludes some potential future developments and new line options on the Central North Island, HVDC and Wairakei Ring. Costing has occurred via the engagement of concept design and/or solution study reports as appropriate. Any options not costed in this way have been approached using our internal knowledge of past projects. We feel this is an acceptable level of accuracy for the Investment Test and note that any final application for construction costs of such options would form part of a Stage 2 application.

5.1.1.1 Preparatory costs

The cost of other options, including new lines, sits across a continuum considering the variability we would face in relation to route, line length, property cost, etc. We have included funding to further investigate the cost of these other options in this application. This funding will be used to either develop detailed designs to enhance existing assets, or start on a process to identify areas, corridors, and potential routes for new lines. This will ensure indicative costs for new lines have a sound basis in subsequent Investment Test analyses. It will also shorten the delivery timeframe if these options are required.

¹⁸ [Transpower Capital Expenditure Input Methodology Determination 2012 \(Principal Determination\)](#)

¹⁹ [TPM current consultations | Transpower](#)

5.1.1.2 HVDC cable upgrade

For the HVDC cable upgrade, a Request for Pricing (RFP) process was undertaken with international vendors. This sought pricing for the manufacture, transport, and installation of appropriate undersea cables. We received a good response to this process and are comfortable with the price accuracy for the purposes of Investment Test analysis.

We are also considering coordination of a new HVDC cable with the end-of-life replacement of our current HVDC cables. It is possible that any final investment decision into the installation of additional HVDC cable capacity would be made in parallel with an investment decision to replace the three existing cables. This would allow us to achieve economies of scale and reduce the costs faced if we proceeded with the two projects independently.

As this is ongoing, we have analysed the HVDC 1400 MW option as an independent project for now.

International demand for undersea cables is high currently, and the lead time for the delivery of a cable or cables to Aotearoa New Zealand is expected to be four to five years. Given this long lead time, we further tested the viability of booking manufacturing capacity to await a trigger point with suppliers. One such trigger would be the confirmed closure of the Tiwai Point smelter. We did this to establish a reduced lead time to installation. This process was unsuccessful with little engagement from the respondents.

5.1.1.3 Outage costs

In some options where existing transmission lines would be upgraded, the outages required to implement parts of the option would have a market cost. Where we assessed the outages as significant, we have undertaken SDDP analysis to determine an approximate likely cost. For the purposes of our Investment Test analysis, we have included that estimated cost.

5.1.2 Expected net electricity market benefit

We have determined the net electricity market benefit for each short-listed option, for each demand and generation scenario. This includes its aggregated quantum of each electricity market benefit or cost element, less the aggregated quantum of each project cost.

The expected net electricity market benefit for each option is the weighted average of the net electricity market benefit under each demand and generation scenario. The weighting is that determined for each demand and generation scenario. In this case, we have used the default weightings of 20% for each of the five scenarios.

5.1.3 Passing the Investment Test

An investment option satisfies the Investment Test if:

- it has the highest expected net electricity market benefit compared to other investment options.
- it has a positive expected net electricity market benefit, unless it is designed to meet an investment need the satisfaction of which is necessary to meet the deterministic limb of the grid reliability standard, and
- it is sufficiently robust under sensitivity analysis.

Some electricity market benefits are unquantified. This occurs when:

- the cost of calculating its quantum is likely to be disproportionately large relative to the quantum, or
- when its expected value cannot be calculated with an appropriate level of certainty due to the extent of uncertainties in underlying assumptions or calculation approaches.

Competition effects may fall into this category because subjective assessments of market behaviour are required to determine their magnitude. Resilience benefits also fall into this category. Currently we do not have a suitable methodology for determining resilience effects to an appropriate level of certainty. However, the effects may be large, especially where an option includes building a new, geographically diverse transmission line. For that reason, we have included funding in NZGP1.1 to develop a suitable methodology which can be used to evaluate our Stage 2 options which include a new line.

5.1.4 Sensitivity analysis

Sensitivity analysis means consideration of the effect on quantum of variations in the following parameters (except where not reasonably practicable nor reasonably necessary):

- forecast demand
- size, timing, location, fuel costs, and operating and maintenance costs relevant to existing assets, committed projects, modelled projects, and the investment option in question
- capital cost of the investment option in question (including variations up to proposed major capex allowance) and modelled projects
- timing of decommissioning, removing, or de-rating decommissioned assets
- the value of expected unserved energy
- discount rate
- range of hydrological inflow sequences
- relevant demand and generation scenario probability weightings
- in relation to any competition effects associated with an investment option, generator offering, and demand-side bidding strategies
- any other variables that Transpower considers to be relatively uncertain.

5.2 Our application of the Investment Test


As discussed above, our long-list of components was reduced to a short-list using some intermediate analysis and application of our strategic considerations, in order to make the necessary analysis tractable. Our short-list of options consists of:

- two HVDC options
- three CNI options, and
- three Wairakei Ring options.

The HVDC options consist of a tactical option to ensure the constancy of transfer capability, plus a new asset option. The CNI and Wairakei Ring options consist of tactical options which squeeze the most out of existing assets and a new asset option. This resulted in 90 SDDP runs plus a Base Case for each scenario.

Diagrammatically, this process is summarised as:

Figure 14: Long list to Proposal Investment Test process



5.2.1 Determining net electricity market benefit

The Investment Test requires that we determine the net benefit for each option studied.

In this case the net benefit is:

Net electricity market benefit = Electricity market benefits – Electricity market costs

This compares the before (investing in the transmission option) cost of meeting electricity demand, with the after cost of meeting electricity demand, for each option and each scenario to 2050.

Formulaically, this could be represented as:

Before cost = $(A + B)_{existgen} + (A + B)_{existgridnm} + (A + B)_{existgridmb} + C_{existgen} + D_{before}$

After cost = $(A + B)_{existgen} + (A + B)_{newgen} + (A + B)_{existgridnm} + (A + B)_{existgridma} + (A + B)_{newgrid} + C_{existnewgen} + D_{after}$

and the net benefit = $(A + B)_{existgen} + (A + B)_{newgen} + (A + B)_{existgridnm} + (A + B)_{existgridma} + (A + B)_{newgrid} + C_{existnewgen} + D_{after} - (A + B)_{existgen} - (A + B)_{existgridnm} - (A + B)_{existgridmb} - C_{existgen} - D_{before}$

= $(A + B)_{newgen} + (A + B)_{existgridma} - (A + B)_{existgridmb} + (A + B)_{newgrid} + C_{existnewgen} - C_{existgen} + D_{after} - D_{before}$

where:

- A = respective capital costs
- B = respective operating and maintenance cost
- C = dispatch costs
- D = unserved energy costs
- existgen = existing generation
- existgridnm = existing grid not modified
- existgridmb = existing grid modified, before modification costs
- existgridma = existing grid modified, after modification costs
- newgen = new generation
- newgrid = new grid
- existnewgen = existing and new generation
- before = before modification
- after = after modification

5.2.2 Investment Test results

For the purposes of applying the Investment Test, we defined the following short-list options for each of the HVDC, CNI and Wairakei Ring combinations

Table 13: Summary of our short-listed options

Short-listed option	HVDC option	CNI option	Wairakei Ring option
Option 1	H1	C6	W1
Option 2	H1	C6	W4
Option 3	H1	C6	W7
Option 4	H1	C8	W1
Option 5	H1	C8	W4
Option 6	H1	C8	W7
Option 7	H1	C9	W1
Option 8	H1	C9	W4
Option 9	H1	C9	W7
Option 10	H2	C6	W1
Option 11	H2	C6	W4
Option 12	H2	C6	W7
Option 13	H2	C8	W1
Option 14	H2	C8	W4
Option 15	H2	C8	W7
Option 16	H2	C9	W1
Option 17	H2	C9	W4
Option 18	H2	C9	W7

Having applied the Investment Test to our short-list, Table 14 shows the expected net market benefit of each short-listed option.

Table 14: Net benefit of shortlist of HVDC and CNI and Wairakei Ring options

Shortlisted option	Expected net market benefit, PV, \$m
Option 1	\$7
Option 2	-\$14
Option 3	\$16
Option 4	\$7
Option 5	-\$16
Option 6	\$14
Option 7	-\$217
Option 8	-\$242
Option 9	-\$211
Option 10	\$176
Option 11	\$150
Option 12	\$181
Option 13	\$173
Option 14	\$145
Option 15	\$175
Option 16	-\$39
Option 17	-\$70
Option 18	\$7

Option 12 maximises expected net market benefit. This option comprises a 1400 MW HVDC link, TTU'ing plus duplexing the TKU-WKM A&B lines, TTU'ing the BPE-TKU A&B lines, TTU'ing the WRK-WKM C line and building a new WRK-WKM D line. The total cost of both stages of Option 12 on a present value basis is \$451 million.

The difference in expected net market benefit between Option 12 and Options 10, 11, 13, 14 and 15 all fall within 10% of the cost of Option 12 and meet the criteria to be considered similar. We have therefore considered unquantified benefits in order to identify the preferred option.

Table 15: Recap of various options

Short-list option	HVDC upgrade	CNI upgrade	Wairakei Ring upgrade
Option 10	1400 MW	TTU and duplex TKU-WKM A&B lines, TTU BPE-TKU A&B lines BRK-SFD reconductoring	TTU WRK-WKM C line
Option 11	1400 MW	TTU and duplex TKU-WKM A& B lines, TTU BPE-TKU A&B lines BRK-SFD reconductoring	TTU WRK-WKM C line and replace WRK-WKM A line
Option 12	1400 MW	TTU and duplex TKU-WKM A& B lines, TTU BPE-TKU A&B lines BRK-SFD reconductoring	Build a new WRK-WKM D line
Option 13	1400 MW	TTU/duplex TKU-WKM A&B lines, TTU/duplex BPE-TKU A& B, TTU BPE-WRK A line BRK-SFD reconductoring	TTU WRK-WKM C line
Option 14	1400 MW	TTU/duplex TKU-WKM A&B lines, TTU/duplex BPE-TKU A& B, TTU BPE-WRK A line BRK-SFD reconductoring	TTU WRK-WKM C line and replace WRK-WKM A line
Option 15	1400 MW	TTU/duplex TKU-WKM A&B lines, TTU/duplex BPE-TKU A& B, TTU BPE-WRK A line BRK-SFD reconductoring	Build a new WRK-WKM D line

Option 10 reflects a tactical option for the CNI – a thermal uprating of the Bunnythorpe to Tokaanu section of the A&B lines, plus duplexing the Tokaanu to Whakamaru section of the A&B lines – plus our tactical option for the Wairakei Ring – a thermal uprating of the Wairakei to Whakamaru C line– plus our tactical option for the HVDC - Stage 1 increases the availability near to 1200 MW transfer. Option 10 also includes the probable addition of a fourth Cook Strait cable as a Stage 2 project for the HVDC, plus BRK-SFD reconductoring.

Option 11 is similar to Option 10 but includes a replacement of the existing Wairakei–Whakamaru A line as a Stage 2 for the Wairakei Ring. The logic applied to the CNI options in section 4.1.2, also applies to the Wairakei Ring and the works in Option 10 may not provide sufficient transmission capacity in some possible futures not evaluated in this analysis. There is merit in including a potential Stage 2 for the Wairakei Ring. We have not done enough work yet to decide whether replacing the existing Wairakei–Whakamaru A line would be more economic than building a new Wairakei–Whakamaru D line, as shown in Option 12, however that would be studied in Stage 2. Replacing the existing A line includes an unquantified benefit in that it ensures Bay of Plenty consumers will have n-1 security of supply at all times. Currently, the Bay of Plenty only has n security when maintenance is undertaken on existing lines. If we undertake a Stage 2 investigation for the Wairakei Ring we would quantify this benefit. Our preference is to proceed with the tactical upgrade and also study which of those two options is most economic. Therefore, we prefer Option 11 over both Option 10 and Option 12.

Option 13 is similar to Option 10 but includes a Stage 2 for the CNI lines north of Bunnythorpe which squeezes the most out of those assets. It is not yet clear whether any Stage 2 should be implementing the second stage of Option 13 or building a new CNI line entirely, but that would be studied in a Stage 2 investigation. However, Option 13 does not include a Stage 2 project for the Wairakei Ring.

Option 14 includes a tactical project for each of the HVDC, CNI and Wairakei Ring, plus a Stage 2 project for each as well. This option has an advantage over the other options, given the uncertainties around the need for Stage 2 projects, but their potential benefit if they are required. It includes a tactical response for each of the HVDC, CNI and Wairakei Ring and reflects an investigation into the need and justification for any Stage 2 projects.

Option 15 does not include a tactical response for the Wairakei Ring and jumps straight to a new D line option. As for Options 11 and 12, more work is required to determine whether replacing the existing A line, or building a new D line is more economic.

Given the extra flexibility of Option 14 to deal with future uncertainty, we prefer this option over all of Options 10, 11, 12, 13 and 15. It is similar to the option with the highest expected net market benefit, Option 12 and the unquantified benefits of extra flexibility mean it is an appropriate choice for our preferred option. The components of Option 14 are described in Table 16.

Table 16: Composition of Option 14

Stage 1 MCP (NZGP1.1)		Possible Stage 2 MCP (NZGP1.2)		
	Project	Expected \$m	Project	Expected \$m
HVDC	Haywards reactive support	84.4	New Cook Strait cable	120
CNI	TTU/Duplex TKU-WKM A&B TTU BPE-TKU A&B	208.0	Reconductor BRK-SFD A line Duplex BPE-TKU A&B TTU BPE-WRK A	75 189 55
Wairakei Ring	TTU WRK-WKM C TTU EDG-KAW 220 kV line	20.7	New/replaced WRK-WKM line	92
Supporting projects		3.5		
Stage 2 preparatory		10.2		

Consistent with the least regrets approach discussed above, we propose to stage all three proposed investments. The first stage contains projects that enhance the capabilities of the existing grid to provide relief for the relevant constraints as soon as reasonably practicable. The second stage contains projects that involve significant changes to grid configuration to relieve the constraints further. We consider it prudent to stage the proposed investment in this way to hedge against the risk of over-investment, given the significant uncertainties about future electricity supply and demand in New Zealand, including when (and if) Tiwai exits and when (and how many) proposed

renewable generation projects in the Wairakei region go ahead. Staging the proposed investment in this way also allows us more time to scope the anticipated projects for NZGP1.2.

It should be noted that this application is to recover the cost of NZGP1.1 only. The costs of any NZGP1.2 projects will be the subject of a separate MCP.

5.3 Investment Test Sensitivities

To test the economic robustness of our proposal, the Capex IM requires that we undertake sensitivity analysis for potentially significant parameters.

For this application of the Investment Test, we considered the following sensitivities relevant:

Table 17: Investment test sensitivities to be reported

Parameter sensitised	Comment
Forecast demand	Reflected in scenarios
Size, timing, location, fuel costs, operating & maintenance costs relevant to existing assets, committed projects, modelled projects, investment option in question	Either reflected in scenarios or included in +/- 30% operating cost sensitivity
Capital cost of proposed investment option (including variations up to proposed MCA) and modelled projects.	Capital cost sensitivity where capital costs are varied +/- 30% are reported
Timing of decommissioning, removing, or de-rating decommissioned assets	Not relevant
Value of expected unserved energy	Not relevant
Discount rate	Sensitivities of 4, 5 and 10 per cent are reported
Range of hydrological inflow sequences	Reflected in scenarios
Relevant demand and generation scenario probability weightings	A range of scenario weightings are included
Competition effects associated with an investment option, generator offering, and demand-side bidding strategies	Not relevant
Other variables that Transpower considers to be relatively uncertain	Tiwai closure date of 2034 sensitivity reported

Table 18 shows how expected net market benefit varies for the short-listed options, for all except the Tiwai closure date sensitivity which is considered separately.

Table 18: Sensitivity of expected net benefit of shortlist of HVDC and CNI and Wairakei Ring options

Sensitivity of expected net benefit to various sensitivities, PV, \$m											
	Sensitivity										
	Investment Test	-30% capital cost	+30% capital cost	-30% ongoing costs	+30% ongoing costs	4% discount rate	5% discount rate	10% discount rate	Scenario weighting 5/10/25/30/30	Scenario weighting 0/10/30/30/30	Scenario weighting 0/0/33/33/33
Option 1	7	94	-80	6	9	212	125	-84	-3	-11	-13
Option 2	-14	93	-121	-14	-14	210	114	-112	-20	-27	-27
Option 3	17	121	-88	15	18	258	156	-92	13	6	7
Option 4	7	134	-120	27	-13	283	165	-114	2	-5	-4
Option 5	-16	130	-162	5	-37	277	152	-143	-18	-25	-23
Option 6	14	157	-130	34	-6	325	193	-123	15	9	12
Option 7	-217	-35	-398	-224	-209	-4	-98	-293	-223	-230	-229
Option 8	-241	-40	-442	-247	-234	-11	-112	-322	-244	-250	-249
Option 9	-211	-13	-409	-219	-203	37	-72	-303	-211	-217	-214
Option 10	176	290	62	172	180	545	390	1	154	141	146
Option 11	150	283	16	147	153	533	372	-29	133	121	127
Option 12	181	312	51	177	186	583	415	-8	167	155	162
Option 13	173	327	20	191	156	609	425	-30	155	142	148
Option 14	145	318	-28	164	126	594	404	-62	129	117	124
Option 15	175	345	5	192	158	641	445	-41	162	150	157
Option 16	-39	169	-247	-49	-29	342	179	-202	-59	-71	-66
Option 17	-70	157	-298	-79	-62	322	153	-236	-87	-99	-92
Option 18	-42	183	-267	-53	-32	366	191	-217	-56	-67	-60

This sensitivity analysis shows differing results from other MCP investigations we have undertaken. For most of our previous MCPs the sensitivity analysis has overwhelmingly supported the choice of our preferred option. This is not the case here due to future uncertainty, which supports the application of a staged MCP.

The sensitivity analysis indicates that any of options 10, 12 or 15 may maximise net benefit, depending upon the circumstances. Option 12 maximises net benefit in the greatest number of sensitivities. From one point of view, it might appear that either Option 12 or 15 should be preferred over Option 14. However, neither Option 12 or 15 include a Stage 2 investigation for each of the HVDC, CNI and Wairakei Ring, which is why they are not preferred. Option 14 has a similar net benefit for several sensitivities, and it remains our preferred option because it does include a Stage 2 investigation for each of the HVDC, CNI and Wairakei Ring. We consider that once the currently unquantified benefits of Option 14 are quantified as part of NZGP1.2 investigations (including the benefit of providing full n-1 security to Bay of Plenty consumers), Option 14 will be preferable to Options 12 or 15.

Since the EDGS do not reflect the full range of future electricity demand or generation uncertainty, it is important that there is a Stage 2 investigation for each of the HVDC, CNI and Wairakei Ring. A significant part of this uncertainty relates to Stage 2 which will be the subject of a further investigation, noting that Stage 1 does not vary between any of options 10-15.

We note the sensitivity of the economic outcome of Option 14 to higher capital cost but point out that this option includes an unquantified benefit (provision of full n-1 security to the Bay of Plenty), which we would expect to lower this sensitivity.

We further note that using a discount rate of 5% would increase the net benefits of our proposal. We have reported the 10% discount rate sensitivity, but that seems an unlikely outcome right now.

In summary, our preference for Option 14 is sufficiently supported by sensitivity analysis and it remains our preferred option.

5.4 Preparatory costs

Our proposal increases HVDC, CNI and Wairakei Ring capacity, first in Stage 1.1 and then again in Stage 1.2. There are possible futures where the incremental upgrades we have included for Stage 1.1 do not provide sufficient capacity and more significant upgrades will be required. The need for these will be investigated and included in NZGP1.2 where economic. Preparatory costs are to investigate those possibilities by preparing the detailed designs for upgrades to existing assets or exploring potential approaches for new assets.

Preparing for NZGP1.2 now balances risks for consumers. On one hand, it requires spending money to develop plans which may then just sit on the shelf and never be used. On the other hand, they are options which can be rolled out at shorter notice if they appear appropriate.

For NZGP1.1 that approach translates to:

- Developing detailed designs for the duplexing of the existing BPE-TKU A and B lines
- Developing detailed designs for the thermal upgrading of the BPE-WRK A line
- Taking forward plans to build a new line north of Bunnythorpe
- Taking forward plans to either replace the WRK-WKM A line, or build a new WRK-WKM D line
- Developing a methodology to quantify resilience benefits. This will support forward planning for a new line north of Bunnythorpe
- Completing a study to consider when and where we may need to consider diversifying our Bunnythorpe substation. This will also support forward planning for a new line north of Bunnythorpe
- Undertaking a lower North Island voltage stability study. It may be necessary to stabilise voltage in order to access the full thermal capacity of our existing assets
- Undertaking a lower North Island system stability study. It may be necessary to increase inertia in the lower North Island, most likely at either Haywards or Bunnythorpe
- Investigating options and the timing for reconductoring a Brunswick-Stratford line

Table 19: List of NZGP1.1 preparatory projects and P50 cost estimates

Preparatory projects (included in Stage 1 MCP)	Supports project	Expected cost \$m
Investigate options for reconductoring a Brunswick-Stratford line	CNI (likely Stage 2 MCP)	2.0
Routes/high level design new WRK-WKM line, or replacement of existing WRK-WKM A line	Wairakei Ring (Stage 2 MCP)	2.0
Detailed design to duplex BPE-TKU A and B lines	CNI (possible Stage 2 MCP)	1.5
Detailed design for TTU of BPE-WRK A line	CNI (possible Stage 2 MCP)	0.5
Routes/high level design new BPE north 220 kV line	CNI (possible Stage 2 MCP)	3.0
Quantifying resilience methodology	CNI (possible Stage 2 MCP)	0.3
Diversification of BPE substation study	CNI (possible Stage 2 MCP)	0.3
Lower NI voltage stability study	CNI (possible Stage 2 MCP)	0.3
Lower NI system stability study	CNI (possible Stage 2 MCP)	0.3
TOTAL		10.2

5.5 MCA calculation

Our proposal comprises the projects listed in Tables 16 and 19.


We have determined the P50 and MCA for each line item individually. Collectively they add up to our NZGP1.1 with the following MCA:

Table 20: List of NZGP1.1 projects, including P50 cost and MCP allowance

Stage 1 Capital Projects	P50 (\$m)	Major Capex Allowance (\$m)
Central North Island	211.5	256.2
HVDC	84.4	103.1
Wairakei Ring	20.7	23.3
Preparatory costs	10.2	10.2
Total	327	393

The MCA is larger than the P50 cost because it includes some scope risk allowances, inflation and interest during construction costs. The MCA of \$393 million represents the maximum cost that Transpower can include in our Regulatory Asset Base for these projects collectively.

Appendix A: Expected impact on transmission charges



A.1 Relationship of the TPM with the Investment Test

The Commerce Commission determines how much revenue Transpower, as the owner and operator of the National Grid, can recover from its customers according to its regulation of Transpower under Part 4 of the Commerce Act (allowable revenue). This includes regulating Transpower's investment decisions through the Capex IM.

The Transmission Pricing Methodology (TPM), set by the Electricity Authority consistent with the TPM Guidelines it approved in June 2020, determines how allowable revenue is recovered from (or allocated to) each of Transpower's customers in each pricing year.²⁰ Once Transpower's capital expenditure proposal has been approved by the Commerce Commission, whether as major capex or base capex, the costs of that investment (and an allowable return on investment) may be recovered through the TPM.²¹

The Commerce Commission has noted:

*The new TPM guidelines and the new TPM [approved by the Electricity Authority in April 2022] under them will not affect the regulatory approval process for assessing the [Major Capex Proposal] under the Capex IM or the amount Transpower can recover in transmission charges for the investment.*²²

Information on indicative transmission charges should the Commerce Commission approve this MCP is detailed in Attachment F and Attachment G.

²⁰ The TPM is Schedule 12.4 to the Electricity Industry Participation Code (the Code), [Part 12 -Transport](#).

²¹ More information about the TPM, including a short [Guide to the TPM](#) is available at [here](#).

²² Commerce Commission [Decision and reasons on Transpower's Bombay Otahuhu Regional MCP](#), 19 March 2021, paragraph 27.

Appendix B: List of Figures and Tables




Figure 1: Key messages	5
Figure 2: Transpower’s enabling role in support of goal to reach net-zero carbon by 2050	7
Figure 3: Strategic considerations informing Transpower’s NZGP Stage 1 investment choices	9
Figure 4: Aotearoa New Zealand transmission grid backbone - the focus of NZGP Phase 1	11
Figure 5: Aotearoa New Zealand transmission grid backbone - the focus of NZGP Phase 2	26
Figure 6: The existing transmission network covered in this MCP	29
Figure 7: Geographic view of the HVDC Cook Strait link	30
Figure 8: Simplified schematic of the existing HVDC link	30
Figure 9: Geographic view of the Central North Island region transmission network	31
Figure 10: Single Line Diagram of the Central North Island (including Wairakei Ring) transmission network.....	32
Figure 11: Geographic view of the Wairakei Ring.....	33
Figure 12: Initiatives being investigated in NZGP1	35
Figure 13: Transmission Planning Report 2022 peak demand forecast	41
Figure 14: Long list to Proposal Investment Test process	58
Table 1: NZGP1.1 at a glance	12
Table 2: Anticipated investments in NZGP1.2	14
Table 3: Sensitivity of expected net benefit of proposal to Tiwai closure assumption on our preferred option.....	17
Table 4: Estimated P50 and MCA costs (\$m) of NZGP1.1 projects.....	19
Table 5: Composition of our original preferred option, Option 10	23
Table 6: Composition of preferred option included in our Addendum, Option 11	24
Table 7: Composition of our updated preferred option, Option 14	25
Table 8: NZGP1 CNI and Wairakei Ring 220kV line end-of-life assumptions.....	39
Table 9: List of Intermediate development plan options	49
Table 10: Short list development plan options matrix	51
Table 11: Options to bypass the existing grid	52
Table 12: Shortlist development options.....	53
Table 13: Summary of our short-listed options	60
Table 14: Net benefit of shortlist of HVDC and CNI and Wairakei Ring options.....	61
Table 15: Recap of various options.....	62
Table 16: Composition of Option 14.....	63
Table 17: Investment test sensitivities to be reported	64
Table 18: Sensitivity of expected net benefit of shortlist of HVDC and CNI and Wairakei Ring options	65
Table 19: List of NZGP1.1 preparatory projects and P50 cost estimates	67
Table 20: List of NZGP1.1 projects, including P50 cost and MCP allowance	68

