
Powerco

Summary statistics 2017 5 year 3 year Rank value trend **CAGR** \$1,593m Regulatory asset base +2.6% 2 2 +2.7% Regulatory profit \$114.6m Return on investment 7.73% 15 \$377.1m +2.1% 2 Line charge revenue Other income +76.3% 4 \$2.2m **Customer connections** 334,042 +1.0% 2 2 Energy delivered 4,531 GWh +1.2% 903 MW 2 Peak demand +1.4% 3,271 MVA +1.8% 2 Network capacity Capital expenditure \$153.6m +9.2% 2 \$73.5m +1.9% Operating expenditure Capital contributions \$25.5m +24.0% 2 \$0.1m -38.4% 27 Related party transactions Line length 28,034km +0.4% 1 +2.3% 19 **Outages - SAIDI** 242 minutes

Capital expenditure

Outages - SAIFI



2.68 faults -

+5.4%

22

3 year ratio	os				
Tota	l capex /	Tota	l capex /	Total capex /	
ass	et base	connections		depreciation	
9.0%	Rank: 24	\$419	Rank: 14	2.31	Rank: 22
Capex by e	xpenditure		Average	5 year	% of

Capex by expenditure category	Average (2015–2017)	5 year trend	% of capex
Asset replacement & renewal	\$56.4m		40.7%
Consumer connection	\$33.3m		24.1%
System growth	\$28.7m		20.7%
Reliability, safety & environment	\$12.8m		9.2%
Non-network assets	\$4.9m	~	3.5%
Asset relocations	\$2.5m		1.8%
Total capital expenditure	\$138.4m		100.0%
Related party transactions	\$0.0m		0.0%

Excel workbook

Explanatory documentation: Link

Line charge revenues

metre of line

Prop	ortion of	Charges	Rank	
	revenue	per unit		
Average daily charge	21.1%	65.4¢/ICP	15	
Delivery (kWh)	52.4%	4.4¢/kWh	9	
Peak based	26.4%	\$110/kW	22	
2014				



Network ratios



Interruption rate: 18.5/100km

Company details

PQ Regulated? Yes

Price breach: No Quality breach: No

CEO: Nigel Barbour

Queensland Investment Corporation 58% Ownership:


AMP Capital-led consortium 42%

Head Office: 2nd Floor, 84 Liardet Street; New Plymouth

06 759 6200 Phone number:

Website: www.powerco.co.nz

Annualised RAB changes (2015-2017)



100m ◆ y-1 forecast

	Not	work	onev	, /		Non	Non-network			/		Tot	al on	ov /	
3 year ratios															
	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27

connections

\$1.09	Rank: 9	\$120	Rank: 4	\$79	Kank: /
Opex by ex	penditure		Average (2015–2017)	5 year trend	% of opex
Business su	ıpport		\$29.7m		42.3%
System ope	erations & netw	ork support	\$10.1m		14.4%
Routine &	corrective main	tenance	\$9.7m		13.9%
Asset repla	cement & renev	wal	\$8.2m		11.6%
Service inte	erruptions & em	ergencies	\$6.8m		9.7%
Vegetation	management		\$5.8m		8.2%
Total opera	nting expenditur	·e	\$70.3m		100.0%
Relat	ed party transa	ctions	\$0.0m		0.0%

Lines and cables

stimated state f the assets	Distribution & LV O/H lines	
uantity	20,224km	
A P. Valuo	¢410.2m	

Summary database: Link







2017

Estimated state					
of the assets D	istribution & LV O/H lines	Distribution & LV U/G cables	Subtransmission lines and cables	Poles	
Quantity	20,224km	6,133km	1,677km	265,674	
RAB Value	\$410.3m	\$333.8m	\$101.5m	*	
Average grade	3.44	3.83	3.81	3.72	
Grade 1 / 2	11.7% / 1.2%	0.7% / 0.0%	1.6% / 0.6%	2.8% / 3.6%	
Unknown grade	0.0%	0.0%	0.0%	1.4%	
Average age	39 years	25 years	35 years	33 years	
Over generic age	1,631km (8.1%)	104km (1.7%)	101km (6.0%)	16,587 (6.2%)	
Unknown age	0.0%	0.0%	0.0%	0.0%	
5yr replacement req (es	t) 12.3%	0.7%	1.9%	4.6%	
5yr planned replacemen	t 4.9%	1.4%	4.5%	5.4%	
Forecast repex (ave)	\$37.5m +32%	\$6.6m +150%	\$4.8m -17%	*	
Repex series –			— ·······	*	

^{*} RAB and expenditure on poles is included within Distribution and LV lines

Switchgear and transformers

Estimated state	
of the assets	Distribution
	transformers

Forecast repex (ave)

Repex series



\$6.9m -9%



\$8.6m +92%






\$14.0m +129%

C - 1 .				
	Distribution ransformers	Distribution switchgear	Zone-substation transformers	Zone-substation switchgear
Quantity	34,805	44,155	211	2,091
RAB Value	\$262.6m	\$145.0m	< \$:	176.9m>
Average grade	3.73	3.57	3.29	3.34
Grade 1 / 2	1.8% / 1.8%	3.1% / 2.8%	5.2% / 1.6%	7.6% / 3.7%
Unknown grade	0.0%	0.0%	0.0%	0.1%
Average age	24 years	24 years	35 years	26 years
Over generic age	5,430 (15.6%)	13,694 (31.0%)	112 (52.9%)	755 (36.1%)
Unknown age	0.0%	0.0%	0.0%	0.0%
5yr replacement req (est)	2.7%	4.5%	6.0%	9.4%
5yr planned replacement	4.9%	8.1%	7.9%	16.5%



Reliability Trend Unplanned Planned 1 Interruptions 3,497 1,701 SAIDI 196.2 45.9 SAIFI 2.45 0.23 CAIDI 79.9 201.6



SAIFI causes									
Equip	Equipment & human error								
Unkn	Unknown								
Obstr	uction								
Weat	her & ex	ternal							
Plann	ed								
40% 0%	10%	20%	30%						

kW